

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306
Sylves
(229

Application Rinnai 011/0146 GPC _____
 Gas Check ☒ Warranty ☒ Inv _____
 New Cust Pkg _____ 5 Yr _____ Letter _____
 Lease/Rent/Amt _____/_____/_____

INVOICE / WORK ORDER NO.

113800

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME Flat creek Church RT# _____ RT. SEQ. _____ ACCT # 1-09071 DATE 6/2/25 INT 25

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 904 Flatcreek Church Rd APT/LOT NO. _____

CITY Nashville STATE GA ZIP CODE 31635

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

Run line, Purchaset, install Rinner

DIRECTIONS:

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____

HOME PH _____ RENT _____

WORK PH _____ CREDIT _____

LITE PILOT _____ PC _____

EMPLOYER _____

DR. _____ USE _____ LEASE _____

email:	JO CRUTCH @ gmail - com
cell #	229-585-0771

PAY BILL ONLINE @congerlpgas.com[illegible]

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	sediment trap / misc B.I				70 00
1	1/2 cut off				29 95
1	B46R				89 95
4	1/2 copper				19 80
1	MIP				19 80
2	1/2 flare nuts				3 95
1	Rinnai REP160cp		PLUA-119966		5 95
					999 95

WORK PERFORMED:	installed rmpai	REGULATION INFORMATION		APPLIANCES/ EQUIP. SOLD	CODE	999 95
	and hooked up	MAKE: Rely	MODEL: TR4	PARTS/MAT. USED		219 60
		DATE CODE: 05P2024	VENT: Down	TANK RENT		

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE
WITH N.F.P.A PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X _____
CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST

HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP:	14 PSI	PSI	START LOCK-UP: W.C.
TANK OFF: PRESSURE	9 PSI	PSI	TANK OFF: PRESSURE W.C.
AFTER 10 MINUTES:	9 PSI	PSI	AFTER 10 MINUTES: W.C.
PRESSURE AS LEFT:	14 PSI	PSI	PRESSURE AS LEFT: W.C.

PIPING PRESSURE TEST

START	PSIG	FINISH	PSIG
-------	------	--------	------

SALES TAX	80.00	1.20
_____ %	17.57	1.92

LABOR		180.00
-------	--	--------

		23 98
Gpc		(400.00)

51		10

INV. TOTAL	1,339.17
AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

710
SERVICE REP. SIGNATURE

6-11-25

x _____