

MBJ / AJ

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 883217	Date Written 6/03/25	Taken By: JC	Schedule Date 6/06/25	Date Completed 6/6/25
Branch - Customer No. 1-16040	Home 229 347-0344	Work Cell	Time Started 11:40/2:18 ^{A.M.} _{P.M.}	Time Completed 12:00 / 4:15 ^{A.M.} _{P.M.}
Name BECKEY ALBRITTON		Head NW on 82, Left on Hick Grove Rd., Lft on Winifred, House on left TK TY WH / LOGS		
Address 751 WINIFRED RD				
City LEESBURG, GA 31763				
Service Address 751 WINIFRED RD. LEESBURG, GA 31763				
Work to be performed: REMOVE OLD TK TYPE WH; INSTALL 50 GL LP WHITE TK TYPE WATER HEATER PER MS ALBRITTON; CALL 347-0344 WHEN ON THE WAY up ✓ Cpp			Work completed BRADFORD Removed old W.H. Installed new W.H.	

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
				1	WT Bradford		899.-
					50 P		
NG	Total		138.46				
	RG250T6X			2	3/4 FIP x 3/4 PEX adp		9.48
				2	3/4 mip x 3/4 PEX adp		8.14
	BC54925754			2	3/4 sharkbite 90°		38.00
				9	3/4 PEX 90°		26.82
				22	3/4 DEX rings		9.24
				1	3/4 PEX cut off		16.80
				22'	3/4 PEX pipe		22.-
				1	1" covl coup		2.34
				1	1" x 3/4 bushing		1.18
				1	3/4 epvc x 3/4 FIP coup		4.38

DR. RT.		Rt. Seq.		Rate		Deposit	
Tank Make		Size 120		Serial NO		CUST OWNED	
Single Stage		Regular Date		Reg. Condition		Mfr.	
TWO		1st					
STAGE		2nd					
Less Check		Flow Check		Lock-up Check			
Manometer Reading at Start 10		Manometer Reading After 10 minutes 10		Manometer Reading Under Load		Manometer Reading	
Central Heating		Water Heater		Range		Clothes Dryer	
Manufacturer		Bradford white					
Model No.		RG250T6X					
Serial No.		BC54925754					
Sed. Trap		Vent					
Fuel/BTU		000		35 000		N/A	
AGE		New					
Shut off Installed							
SHOP OR TRUCK SUPPLIES		16.50					
MATERIAL TOTAL		1053.96					
TRIP CHARGE							
LABOR		340.-					
SUB-LABOR		Rebate		<200.00>			
PERMIT							
SHIPPING/FREIGHT							
Thank You		SALES TAX		84.32			
		TOTAL		1278.28			

☐ CASH		RECEIVED BY	
☐ CHECK			
Work Completed by: Mike & AJ		Date 6/6/25	
Customer Signature: Beckey Albritton		Date 6/6/25	
I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY			
ANY UNUSED GAS PIPING OUTLETS INDOORS?		☐ YES ☐ NO	
IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?		☐ YES ☐ NO	
CUSTOMER AVAILABLE		☐ YES ☐ NO	
CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE		☐ YES ☐ NO	