



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

Application Rinnai GPC
Gas Check Warranty Inv
New Cust Pkg 5 Yr Letter
Lease/Rent/Amt _____

INVOICE / WORK ORDER NO.

111527

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME CNK Properties RT# _____ RT. SEQ. _____ ACCT # 01

22884

DATE 11-20-24 INT BM

MAILING ADDRESS P.O. Box 7711, Tifton, GA 31793 CO. _____ CITY _____

ADDRESS 2217 Melanna Dr. APT/LOT NO. _____

CITY Tifton STATE GA ZIP CODE 31793

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: info@kunasrealestate.com

cell # 229-402-0990

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

Meet Nelson - 402-0990

Wants tankless water heater as soon as possible

DIRECTIONS:



Thursday 11th Call
Must after lunch

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
	120	1528534	4	On Site					

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	2 1/2" x 8"				5.00
20'	1/2" COPPER				119.00
2	1/2" FLOWMETER				5.95
1	M.P.				3.95
1	Sediment Trap				50.00
1	Control Valve				29.95
1	1/4" R.P.				77.95
1	Rinnai	RL752P	PLC-A036276		899.95

WORK PERFORMED: <u>Set 120, Install w/1/4"</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE	899.95
<u>Rin line</u>	MAKE: <u>Rinnai</u>	MODEL: <u>RL75</u>	PARTS/MAT. USED	<u>MP</u>	313.90
	DATE CODE: <u>8A2023</u>	VENT: <u>DDW1</u>	TANK RENT		

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:			LEAK AND PRESSURE TEST		SALES TAX	08	72.00
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>	HIGH:	1st Stage	2nd Stage	LOW			25.11
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	START LOCK-UP:	11 PSI	PSI	START LOCK-UP:	W.C.	LABOR	180.00
	TANK OFF PRESSURE:	9 PSI	PSI	TANK OFF PRESSURE:	W.C.		
	AFTER 10 MINUTES:	9 PSI	PSI	AFTER 10 MINUTES:	W.C.		
	PRESSURE AS LEFT:	11 PSI	PSI	PRESSURE AS LEFT:	W.C.		
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.			PIPING PRESSURE TEST		INV. TOTAL		1507.01
X _____ CUSTOMER SIGNATURE			START	PSIG	FINISH	PSIG	AMOUNT RECEIVED
							1107.01

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

[Signature]
SERVICE REP. SIGNATURE

11-20-24
DATE

X

CUSTOMER SIGNATURE