



146 S. Ridge Ave.  
Tifton, GA 31794  
(229) 386-5574

Application 2 Rinnai 2 GPC 2  
Gas Check 2 Warranty 2 Inv 2  
New Cust Pkg 25 Yr Letter 2  
Lease/Rent/Amt COT

INVOICE / WORK ORDER NO.

111143

3117 Veterans Parkway S.  
Moultrie, GA 31788  
(229) 985-6942

NAME Saldanha, Gerald RT# 03-20711 DATE 11-19-24 INT 10

MAILING ADDRESS \_\_\_\_\_ CO. \_\_\_\_\_ CITY \_\_\_\_\_

ADDRESS 603 Black Acres APT/LOT NO. \_\_\_\_\_

CITY Moultrie STATE GA ZIP CODE 31768

NEW CUSTOMER INFORMATION

S.S. NO. \_\_\_\_\_ DELV \_\_\_\_\_  
HOME PH \_\_\_\_\_ RENT \_\_\_\_\_  
WORK PH \_\_\_\_\_ CREDIT \_\_\_\_\_  
LITE PILOT \_\_\_\_\_ PC \_\_\_\_\_  
EMPLOYER \_\_\_\_\_  
DR. \_\_\_\_\_ USE \_\_\_\_\_ LEASE \_\_\_\_\_

email: geraldoben@hotmail.com

cell # 229-319-5584

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED \_\_\_\_\_

install water heater

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
	<u>250</u>	<u>COT</u>			MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>RLTS ep</u>		<u>PD.CA-06</u>	<u>99.34</u>	<u>99.95</u>
<u>1</u>	<u>Shut off</u>				<u>19.95</u>
<u>1</u>	<u>Misc Iron</u>				<u>60.00</u>
<u>10</u>	<u>Copper</u>				<u>49.95</u>
<u>2</u>	<u>Flange Nuts</u>				<u>4.18</u>

WORK PERFORMED: <u>Install TWH</u>	REGULATION INFORMATION		APPLIANCES/ EQUIP. SOLD	CODE	<u>999.95</u>
<u>@ COT gas ck no</u>	MAKE: <u>Rego</u>	MODEL: <u>B9</u>	PARTS/MAT. USED	<u>MP</u>	<u>134.08</u>
<u>Leaky</u>	DATE CODE: <u>3-00</u>	VENT: <u>Hor</u>	TANK RENT	<u>WS</u>	<u>18.84</u>
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE					<u>CP 14.95</u>
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:			SALES TAX	<u>1.51</u>	<u>8000</u>
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>	LEAK AND PRESSURE TEST		LABOR	<u>120</u>	<u>10.73</u>
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	HIGH: 1st Stage	2nd Stage	LOW		
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	START LOCK-UP: PSI	PSI	START LOCK-UP: <u>13.4</u> W.C.	<u>LB</u>	<u>180.00</u>
	TANK OFF: PRESSURE PSI	PSI	TANK OFF: PRESSURE <u>9</u> W.C.	<u>(GPC)</u>	<u>400.00</u>
	AFTER 10 MINUTES: PSI	PSI	AFTER 10 MINUTES: <u>9</u> W.C.		
	PRESSURE AS LEFT: PSI	PSI	PRESSURE AS LEFT: <u>13.4</u> W.C.		
X	PIPING PRESSURE TEST		INV. TOTAL		<u>1041.26</u>
CUSTOMER SIGNATURE	START	PSIG	FINISH	PSIG	AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE