CONGER FUELING LIFE LP GAS

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S.
Sylveste
(229)

Application ✓ Rinnai 7695/6696 GPC ____
Gas Check ____ Warranty ✓ Inv —
New Cust Pkg ____ 5 Yr ____ Letter ✓
Lease/Rent/Amt ____/____/ 10

INVOICE / WORK ORDER NO.

111160

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME Avery Hoover RT# ____ RT. SEQ. ____ ACCT # 03-22193 DATE 11-19-24 INT DB

MAILING ADDRESS 2900 US 19 N CO. ____ CITY ____

ADDRESS ____ APT/LOT NO. ____

CITY Pelham STATE GA ZIP CODE 31779

NEW CUSTOMER INFORMATION

S.S. NO. ____ DELV ____
HOME PH ____ RENT ____
WORK PH ____ CREDIT ____
LITE PILOT ____ PC ____
EMPLOYER ____
DR. ____ USE ____ LEASE ____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED ____

email: Sowegabeagles@gmail.com
cell # 219.314-2364
PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: Install TWH

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
	120	1528257	10	Gallon					
	250		need gas order						

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	RL 75 ep	RL75e	PDCA-069936		999.95
160	Feet 1/2 poly				96.00
1	1/2 poly TEE				39.95
1	Regulator.				64.95
2	Copper Cert.				139.90
	10 * 3.899 = 38.99 + 4.32 + 14.95			=	58.26

WORK PERFOMED: Set 120 tank Run new gas line to water Heater.

REGULATION INFORMATION
MAKE: Rego MODEL: 346R
DATE CODE: 8-23 VENT: Down.

	CODE	
APPLIANCES/ EQUIP. SOLD	WH	999.95
PARTS/MAT. USED	MP	340.80
~~TANK RENT~~	DS	42.05
	CF	14.95
SALES TAX ____ %		3.36 80.00 / 1.20 27.24
LABOR	LB	360.00
	TR	10.00
	GPC	200.00
INV. TOTAL		1238.63
AMOUNT RECEIVED		

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X ____ CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST

HIGH:	1st Stage	2nd Stage	LOW	
START LOCK-UP:	PSI	PSI	START LOCK-UP: 11.8	W.C.
TANK OFF: PRESSURE	PSI	PSI	TANK OFF: PRESSURE 9	W.C.
AFTER 10 MINUTES:	PSI	PSI	AFTER 10 MINUTES: 9	W.C.
PRESSURE AS LEFT:	PSI	PSI	PRESSURE AS LEFT: 11.5	W.C.

PIPING PRESSURE TEST

START ____ PSIG FINISH ____ PSIG

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

D. Dwayne
SERVICE REP. SIGNATURE

11/2/2024
DATE

x ____ CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY; BLUE/OFFICE COPY