



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S.
Sylvester
(229) 7

Application ☒ Rinnai ☐ GPC
Gas Check ☒ Warranty ☒ Inv ☐
New Cust Pkg ☐ 5 Yr ☐ Letter ☒
Lease/Rent/Amt 414 / 30

INVOICE / WORK ORDER NO.

109556

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME Thomas M Ellis II RT# AT RT. SEQ. ACCT # 01-22594 DATE 10/30/24 INT AP

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 336 Platte Road APT/LOT NO. _____

CITY Fitzgerald STATE GA ZIP CODE 31750

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: Tomellis5479@gmail.com
cell # 229-740-8954

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

Hook up Generators for house,
The Generator people will be there to
DIRECTIONS: install Generator 11-1-24 @ 1:00 and they want
it ready for them
11-5-24 10am

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
TS	250	1528230	●	On Site	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
10	Gallons Propane			3749	3749
150	3/4 Poly				150 00
3	Poly Risers				374 85
1	Poly Tee				1018 95
1	Rinnai Tankless Water Heater	RE1992	SC-UA-029319		1399 95
1	Peterson Burner 30" w/ CHAS Logs	G10-24/30-D1VP	2006756		1799 95
	Misc. Black Iron				69 80
2	Butt Regulator				159 90
3	Cutoff Valve				84 85

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>Set 250, french gas</u>	MAKE: <u>Rego</u> MODEL: <u>TR9</u>	PARTS/MAT. USED	WH
<u>line to generator, Rinnai & logs</u>	DATE CODE: <u>1282023</u> VENT: <u>Down</u>	TANK RENT	TR
			CF

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX		
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.E.P.A. PAMPHLET NUMBER 58 ☐		HIGH: 1st Stage 2nd Stage LOW		8 %	27	112.00
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.E.P.A. PAMPHLET NUMBER 54 ☐		START LOCK-UP: 11 PSI				129.60
		TANK OFF: PRESSURE 7 PSI				2.40
		AFTER 10 MINUTES: 7 PSI				1.20
		PRESSURE AS LEFT: 11 PSI				86.62
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		START LOCK-UP: 11 PSI				9.62
		TANK OFF: PRESSURE 7 PSI				14.00
		AFTER 10 MINUTES: 7 PSI				3.00
		PRESSURE AS LEFT: 11 PSI				
X _____ CUSTOMER SIGNATURE		PIPING PRESSURE TEST		10 gals	01	37.49
		START PSIG FINISH PSIG		Invoice Total		5809.10

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE