



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

30¢
Sylve:
(22

Application Rinnai GPC
Gas Check ✓ Warranty Inv
New Cust Pkg 5 Yr Letter ✓
Lease/Rent/Amt COT

INVOICE / WORK ORDER NO.

110721

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME Toni Gregory Deely Campground RT# _____ RT. SEQ. _____ ACCT 1-22945 DATE 11-26-24 INT _____

MAILING ADDRESS 16920 GA Highway 27 CO. _____ CITY _____

ADDRESS _____ APT/LOT NO. _____

CITY Vienna STATE GA ZIP CODE 31092

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

Chad Turner called - looking at regulator
when comes out of ground - turned tank
DIRECTIONS: off -

Toni Gregory 404-226-0963
229-406-0903

NEW CUSTOMER INFORMATION
S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: toni.gregory@bellsouth.net
cell # _____

PAY BILL ONLINE @congerlpgas.com

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
		<u>COT - UG</u>			MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>Rinnai tankless</u>	<u>RL75c</u>	<u>PCCA-036609</u>	<u>(WH)</u>	<u>999.95</u>
	<u>24" logs with remote</u>	<u>71-VF9-12PCM</u>	<u>2005635</u>	<u>(AP)</u>	<u>1099.95</u>
	<u>Anode bag</u>				<u>299.95</u>
	<u>Sediment trap withutoff valve</u>				<u>44.95</u>
	<u>LV4403B46R regulator</u>				<u>79.95</u>
	<u>LV4403TA9 regulator</u>				<u>79.95</u>
<u>28'</u>	<u>3/8" copper</u>			<u>3.95</u>	<u>110.60</u>
<u>36'</u>	<u>1/2" copper</u>			<u>4.95</u>	<u>128.20</u>
	<u>3/8 cutoff valve</u>				<u>19.95</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>Buried tank installed</u>	MAKE: <u>Rego</u> MODEL: <u>TR9</u>	<u>(MP)</u>	<u>1394.25</u>
<u>tankless w/h, gas logs, stove</u>	DATE CODE: <u>0902022</u> VENT: <u>UL</u>	<u>(MS)</u>	<u>155.66</u>
		TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:	LEAK AND PRESSURE TEST	SALES TAX
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH: 1st Stage 2nd Stage LOW	%
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	START LOCK-UP: <u>9.3</u> PSI	LABOR
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: <u>6.0</u> PSI	<u>(GR)</u> <u>(200.00)</u>
	AFTER 10 MINUTES: <u>6.0</u> PSI	
	PRESSURE AS LEFT: <u>9.0</u> PSI	
X	PIPING PRESSURE TEST	INV. TOTAL
CUSTOMER SIGNATURE	START <u>6.0</u> PSIG FINISH <u>6.0</u> PSIG	AMOUNT RECEIVED <u>4957.95</u>

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

James + Justin
SERVICE REP. SIGNATURE

12-10-24
DATE

X

CUSTOMER SIGNATURE