

- SALES
- SERVICE
- INSTALLATION



R

1-11 Call

Mike

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

AJ

| | | | | |
|--|--|--------------------|--|------------------------------|
| Order Number 874761 | Date Written 11/05/24 | Taken By JC | Schedule Date 11/20/24 | Date Completed 11/20/24 |
| Branch - Customer No. 1-06424 | Home 407 466-6291 | Work | Time Started 10:20 P.M. | Time Completed 12:30 P.M. |
| Name TIM DWYER | Address 941 WEST MORSE BLVD ST200 City WINTER PARK, FL | Cell 32789-3781 | LESLIE LFT 280 LF BIG WHITE CH ON HUNTINGTON ABOUT 1 MILE. UG TANK 2 RINNAI HW, 2 FP'S, COOK & GRILL | |
| Service Address 287 HUNTINGTON ROAD AMERICUS, 31709-5911 | Work to be performed: DELIVER & INSTAL 2 NEW RL75EP WATER HEATERS; HOOK UP CONTROLLERS; INSTALL 2 PCD03SM2 PIPE COVERS; PER MR DWYER (407-466-6291) | | | |
| Work completed Removed 2 old Rinnai's Installed 2 New Rinnai's w/ pipe cover. | | | | |

Up ✓ Copy

| Qty: | Materials | Price | Amount | Qty: | Materials | Price | Amount |
|------|-----------------------|-------|--------------|------|-------------|-------|---------|
| 4 | 3/4 FIP x 3/4 PEX Adp | 4.74 | 18.96 | 2 | WR RL 75e P | 902.- | 1,804.- |
| 4 | 3/4 Sharkbite coup. | 15.66 | 62.64 | | | | |
| 4 | 3/4 PEX rings | .42 | 1.68 | 2 | WR PCD03SM2 | 167.- | 334.- |
| 1 | 3/4 PEX PIPE | | 1.- | | | | |
| | Total | | 84.28 | | | | |

| | | | |
|--------------|--------------|-----------------|---------------------------------|
| DR. RT. | Rt. Seq. | Rate | Deposit |
| Tank Make | Size 330 | Serial No. 6733 | Tank Percent |
| Single Stage | Regular Date | Reg. Condition | Mfr. Model Vent Pos. Protected? |
| TWO 1st | | | |
| STAGE 2nd | Replacement | | |

| | | | | | |
|----------------------------------|--|--|------------------------------------|------------------------|-------|
| Manometer Reading at Start 10 | Less Check Manometer Reading After 10 minutes 10 | Flow Check Manometer Reading Under Load | Lock-up Check Manometer Reading | SHOP OR TRUCK SUPPLIES | 14:50 |
|----------------------------------|--|--|------------------------------------|------------------------|-------|

| Manufacturer | Model No. | Serial No. | Sed. Trap | Vent | Fuel/BTU | AGE | Shut off Installed |
|--------------|-----------|--------------|-----------|------|----------|------|--------------------|
| Rinnai 1 | RL75e | PC.CA-043166 | NO | YES | 180,000 | 2019 | Yes |
| Rinnai 2 | RL75e | PD.CA-067738 | NO | YES | 180,000 | 2019 | Yes |

| | |
|-------------------|------------------|
| MATERIAL TOTAL | 2236 78 |
| TRIP CHARGE | |
| LABOR | 340 - |
| SUB-LABOR: Rebate | <400 00> |
| PERMIT | |
| SHIPPING/FREIGHT | |
| Thank You | SALES TAX 178 94 |
| | TOTAL 2355 72 |

CASH
 CHECK

RECEIVED BY
 Work Completed by Mike + A.J. Date 11/20/24
 Customer Signature [Signature] Date 11/20/24

ANY UNUSED GAS PIPING OUTLETS INDOORS? YES NO
 IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? YES NO
 CUSTOMER AVAILABLE YES NO
 CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE YES NO

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY