



congerlpgas.com

INVOICE / WORK ORDER NO.

110772

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574306 S. Main St.
Sylvester, GA 31791
(229) 776-7336604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-87223117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942NAME Rhane Deane RT# _____ RT. SEQ. _____ ACCT # 2-14088 DATE 11-11 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 914 Oak Hill Drive APT/LOT NO. _____CITY Albany STATE _____ ZIP CODE 31791

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

email: _____

cell # 606-9-2538

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: _____

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	AL75 Rhane WH Rhane pipe cover kit	RL75E	RCA-036280	(WH) (MP) (MS)	999.95 214.95 23.70

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/ EQUIP. SOLD	CODE
installed AL75 Changed Over WH	MAKE: <u>REGO</u> MODEL: <u>TR9</u>	PARTS/MAT. USED	
	DATE CODE: <u>11A06</u> VENT: <u>Down</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST			SALES TAX _____%	LABOR	INV. TOTAL	AMOUNT RECEIVED
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐		HIGH:	1st Stage	2nd Stage	LOW			
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐		START LOCK-UP:	9.2 PSI	23 PSI	START LOCK-UP: 13.1 W.C.			
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE	6.0 PSI	1.5 PSI	TANK OFF: PRESSURE 20 W.C.	(BR)	200.00	
		AFTER 10 MINUTES: PRESSURE	6.0 PSI	1.5 PSI	AFTER 10 MINUTES: 20 W.C.			
		AS LEFT: PRESSURE	9.0 PSI	20 PSI	AS LEFT: 11.0 W.C.			
X _____ CUSTOMER SIGNATURE		PIPING PRESSURE TEST					1333.85	
		START	6.0 PSIG	FINISH	6.0 PSIG			

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Service Rep. Signature
SERVICE REP. SIGNATURE11-11-2024
DATE

x

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY; BLUE/OFFICE COPY