



congerlpgas.com

110721

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

NAME Toni Gregory Woolly Campground RT# _____ RT. SEQ. _____ ACCT# 1-22945 DATE 11-26-24 INT _____

MAILING ADDRESS 16920 GA Highway 27 CO. _____ CITY _____

ADDRESS _____ APT/LOT NO. _____

CITY Vienna STATE GA ZIP CODE 31092

NEW CUSTOMER INFORMATION	
S.S. NO. _____	DELV _____
HOME PH _____	RENT _____
WORK PH _____	CREDIT _____
LITE PILOT _____	PC _____
EMPLOYER _____	
DR. _____	USE _____ LEASE _____

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

Chad Turner called - looking at regulator when cones out of ground - turned tank

DIRECTIONS: off - Toni Gregory 404-226-0963

229-406-0903

email: toni.gregory@bellsouth.net
cell # _____
PAY BILL ONLINE @congerlpgas.com

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
		<u>COT - UG</u>							

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>Rinnai tankless</u>	<u>RL75c</u>	<u>PCCA-036609</u>	<u>(WH)</u>	<u>999.95</u>
	<u>24" logs with remote</u>	<u>71-VF9-12PLM</u>	<u>2005635</u>	<u>(AP)</u>	<u>1099.95</u>
	<u>Anode bag</u>				<u>299.95</u>
	<u>Sediment trap with cutoff valve</u>				<u>44.95</u>
	<u>LV4403B46R regulator</u>				<u>79.95</u>
	<u>LV4403TR9 regulator</u>				<u>79.95</u>
<u>28'</u>	<u>3/8" copper</u>			<u>3.95</u>	<u>110.60</u>
<u>36'</u>	<u>1/2" copper</u>			<u>4.95</u>	<u>128.20</u>
	<u>3/8" cutoff valve</u>				<u>19.95</u>

WORK PERFORMED: <u>Buried tank installed</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE	SALES AMOUNT
<u>tankless w/h, gas logs, stove</u>	MAKE: <u>Rego</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED	<u>(MP)</u>	<u>1394.25</u>
	DATE CODE: <u>0902023</u>	VENT: <u>uc</u>	TANK RENT	<u>(MS)</u>	<u>155.66</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:	LEAK AND PRESSURE TEST			SALES TAX	
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>	HIGH: 1st Stage	2nd Stage	LOW	_____ %	
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/>	START LOCK-UP: <u>9.3</u> PSI	PSI	START LOCK-UP: <u>13.2</u> W.C.	LABOR	<u>1200.00</u>
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: PRESSURE <u>6.0</u> PSI	PSI	TANK OFF: PRESSURE <u>9.0</u> W.C.	<u>(GR)</u>	<u>(200.00)</u>
	AFTER 10 MINUTES: <u>6.0</u> PSI	PSI	AFTER 10 MINUTES: <u>9.0</u> W.C.		
	PRESSURE AS LEFT: <u>9.0</u> PSI	PSI	PRESSURE AS LEFT: <u>11.0</u> W.C.		
X _____	PIPING PRESSURE TEST			INV. TOTAL	
CUSTOMER SIGNATURE	START <u>6.0</u> PSIG	FINISH <u>6.0</u> PSIG	AMOUNT RECEIVED		<u>4957.95</u>

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Jerry & Justin SERVICE REP. SIGNATURE 12-10-24 DATE X _____ CUSTOMER SIGNATURE