



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S.
Sylvester,
(229) 7

Application Rinnai 10163 GPC
Gas Check ☒ Warranty ☒ Inv
New Cust Pkg 5 Yr Letter
Lease/Rent/Amt

INVOICE / WORK ORDER NO.

113625

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME HOWARD LENTER Jessica Stoppel RT# RT. SEQ. ACCT # 01-19384 DATE 5-21-25 INT EA
1-21914

MAILING ADDRESS CO. CITY

ADDRESS 67 Goat Rd APT/LOT NO.

CITY Tifton STATE GA ZIP CODE 31794

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED

NEW CUSTOMER INFORMATION	
S.S. NO. <u> </u>	DELV <u> </u>
HOME PH <u> </u>	RENT <u> </u>
WORK PH <u> </u>	CREDIT <u> </u>
LITE PILOT <u> </u>	PC <u> </u>
EMPLOYER <u> </u>	
DR. <u> </u>	LEASE <u> </u>

email: jwh.hey1256@gmail.com

cell # 229-472-0769

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: TP-120, TS 500, Run line to pool house.
Install water heaters & grill, griddle, WH, firepit, logs
See acct # 1-21914

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
TP	120	U-147554	65	Bulk Plant	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
TS	500	633843	0	ON SITE	(78) Gals	@ 3	699	(288.52)	

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rinnai	RSC199CP	REBA-064843		1299 95
1	30" CHAS Peterson	G10-24/30-0100	2065687	1529.96	1529.96
190'	3/4 POLY				180 50
1	3/4 Rigid Riser				159 95
1	3/4 Poly Tee				119 95
2	3/4 Poly Transitions				89 80
20'	1/2 COPPER				99 00
6	1/2 flare nuts				17 70
	Trench Fes				125 00

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD
Set tank, Run line to	MAKE: <u>REGA</u> MODEL: <u>TR9</u>	<u>WH</u> 1,529.96
WH's, griddle, oven, burner, logs	DATE CODE: <u>8B2023</u> VENT: <u>DOWN</u>	<u>MP</u> 2,084.70
+ firepit.		<u>CF</u> 14 95

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST			
HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP:	11 PSI	PSI	START LOCK-UP:
TANK OFF: PRESSURE	9 PSI	PSI	TANK OFF: PRESSURE
AFTER 10 MINUTES:	9 PSI	PSI	AFTER 10 MINUTES:
PRESSURE AS LEFT:	11 PSI	PSI	PRESSURE AS LEFT:

SALES TAX	08	122.40 (23.08)
		104.00 20.81
		166.40 10.00
LABOR	LB	2,250.00
W.C.	(78) Gals	01 (288.52)
W.C.	ms	260.08
W.C.	Trencher	EQ 125.00

PIPING PRESSURE TEST			
START	PSIG	FINISH	PSIG

INV. TOTAL	7,678.23
AMOUNT RECEIVED	GPC (200.00)

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Emmi Puhlar
SERVICE REP. SIGNATURE

5-22-25
DATE

X

 CUSTOMER SIGNATURE