



congerlpgas.com

INVOICE / WORK ORDER NO.

121407

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Savannah Bischof RT# _____ RT. SEQ. _____ ACCT # 2-21887 DATE 6-10-25 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 122 N Cotton St APT/LOT NO. _____

CITY Poulan STATE GA ZIP CODE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: _____

cell # 229-352-7721

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

wed or Thurs - of this week(?)
wants quote on tankless w/h
installation

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
TS	250	5439	0						
TS	120	1A103207	100%						

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>Rinnai</u>	<u>REPI40e</u>	<u>PKUA-113454</u>	<u>(WH)</u>	<u>999.95</u>
	<u>Sediment trap with cutoff valve</u>				<u>44.95</u>
	<u>LV4403B46R regulator</u>				<u>79.95</u>
2	<u>1/2" flare nut</u>			<u>2.95</u>	<u>5.90</u>
2	<u>1/2x1/2 nip</u>			<u>3.95</u>	<u>7.90</u>
2	<u>1/2" copper</u>			<u>4.95</u>	<u>9.90</u>
				<u>(MP)</u>	<u>148.60</u>

WORK PERFORMED: <u>Set 120. Installed</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE
<u>tankless w/h</u>	MAKE: <u>Rego</u>	MODEL: <u>LV3403TR9</u>	PARTS/MAT. USED	<u>(MS)</u>
	DATE CODE: <u>1202021</u>	VENT: <u>Down</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X

CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST			
HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP:	<u>9.3</u> PSI	PSI	START LOCK-UP: <u>13.2</u> W.C.
TANK OFF: PRESSURE	<u>6.0</u> PSI	PSI	TANK OFF: PRESSURE <u>9.0</u> W.C.
AFTER 10 MINUTES: PRESSURE	<u>6.0</u> PSI	PSI	AFTER 10 MINUTES: <u>9.0</u> W.C.
PRESSURE AS LEFT:	<u>9.0</u> PSI	PSI	PRESSURE AS LEFT: <u>11.0</u> W.C.

PIPING PRESSURE TEST			
START	<u>6.0</u> PSIG	FINISH	<u>6.0</u> PSIG

SALES TAX _____ %		
LABOR		<u>180.00</u>
	<u>GR</u>	<u>(200.00)</u>
INV. TOTAL		<u>1268.69</u>
AMOUNT RECEIVED		

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE