



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

30¢
Sylve:
(22

Application e Rinnai GPC
Gas Check ✓ Warranty Inv e
New Cust Pkg e 5 Yr e Letter ✓
Lease/Rent/Amt e e e

INVOICE / WORK ORDER NO.

113414

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME LNK Properties RT# _____ RT. SEQ. _____ ACCT # 01-22938 DATE 3-20-25 INT EP

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 113 Branch St APT/LOT NO. _____

CITY Tifton STATE GA ZIP CODE 31793

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: in Ab@kingsredestate.com
cell # 229-386-0440

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

Set tank (vertical) 120
Install Rinnai REPI 160
Call Dustin Pitts about electrical

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
<u>TS</u>	<u>120</u>	<u>2594522</u>	<u>✓</u>	<u>ON SITE</u>	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>20</u>	<u>20 gallons</u>			<u>3.999</u>	<u>79.98</u>
<u>1</u>	<u>Rinnai</u>	<u>REP160E</u>	<u>PLUA119983</u>		<u>899.95</u>
<u>1</u>	<u>B46R Regulation</u>				<u>89.95</u>
<u>1</u>	<u>Sediment</u>				<u>50.00</u>
<u>1</u>	<u>Cutoff</u>				<u>29.95</u>
<u>15'</u>	<u>3/8 COPPER</u>				<u>59.25</u>
<u>2</u>	<u>3/8 flare Nuts</u>				<u>5.95</u>
<u>1</u>	<u>MID</u>				<u>3.95</u>
	<u>MISC supplies</u>				<u>25.14</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>Set tank, Ran line</u>	MAKE: <u>Rejo</u> MODEL: <u>TR9</u>	PARTS/MAT. USED	
<u>Install w/it</u>	DATE CODE: <u>162025</u> VENT: <u>DOWN</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐		HIGH: 1st Stage 2nd Stage LOW		____ %
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐		START LOCK-UP: <u>11</u> PSI <u>PSI</u> START LOCK-UP: <u>W.C.</u> LABOR		<u>72.00</u> <u>2.01</u>
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE <u>7</u> PSI <u>PSI</u> TANK OFF: PRESSURE <u>W.C.</u>		<u>19.12</u> <u>4.40</u>
		AFTER 10 MINUTES: <u>9</u> PSI <u>PSI</u> AFTER 10 MINUTES: <u>W.C.</u>		<u>120</u> <u>6.40</u>
		PRESSURE AS LEFT: <u>11</u> PSI <u>PSI</u> PRESSURE AS LEFT: <u>W.C.</u>		<u>180.00</u>
X _____ CUSTOMER SIGNATURE		PIPING PRESSURE TEST		
		START PSIG FINISH PSIG	INV. TOTAL	
			AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Evan Finkbein
SERVICE REP. SIGNATURE

6-30-25
DATE

X

CUSTOMER SIGNATURE