

Route



HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

INVOICE
No. 10922

NAME	<u>Cindy Claxton</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>126 Claxton Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Hazlehurst GA 31539</u>	DATE PROMISED	
PHONE	<u>912-424-4712</u>	DATE COMPLETED	<u>7-11-25</u>
LOCATION		TERMS	

INSTRUCTIONS set 120 gallon tank, install tankless water heater

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RL75a tankless water heater w/isolation		1285 00
	valves & T-pad, serial# PC-CA-037570		
100	gallon of propane	2 99	299 00
1	6 X6 EPVC box for T-pad		38 00
1	Rego LV3403B4 second stage regulator		59 95
52'	1/2" coated copper tubing	3 49	181 48
6	1/2" flare nut	1 60	9 60
1	1/2" cut off valve		16 95
1	1/2" swivel		3 99
all	other gas fittings, 2-px fittings, thread sealant		27 40

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

set 120 gallon tank, installed tankless water heater, ran gas line, ran pressure check, lit & checked out water heater

TOTAL MATERIAL

1921 37

TOTAL TIME

HOURS

LABOR

400 00

THE ODOOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

Daniel

SUBTOTAL

SALES TAX

153 71

TOTAL DUE

2475 08

X CUSTOMER'S SIGNATURE

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION & OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>120</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>1237249</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>100gal</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

-GPA rebate 200.00
AMOUNT

2,275.08

RECEIVED BY

DATE

SERVICES RECEIVED BY

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

Total owed: \$ 711.22

GASCheck – Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 7/11/25
 Name Cindy Claxton Company Sikes Propane, Inc.
 Address 126 Claxton Rd. Call Taken By _____
 City Hazlehurst State GA Zip 31539 Telephone (Cell) 912-424-4712 (Home) _____

Appliance Check

Appliance	<u>water heater</u>					
Manufacturer	<u>Rinnai</u>					
Model #	<u>RL75e</u>					
Serial #	<u>PC, CA-03 7570</u>					
BTU's	<u>180,000</u>					
Burner / Com. Chamber	<u>ok</u>					
Man. Shutoff / Sed. Trap	<u>installed</u>					
Control / Pilot Safety System	<u>ok</u>					
Venting System	<u>ok</u>					
Age	<u>new</u>					
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>1237249</u>	<u>Quality Steel</u>	<u>2017</u>	<u>ok</u>	<u>ok</u>	<u>4E17</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>135 psi.</u>	<u>135 psi.</u>	<u>10 min.</u>	<u>0</u>	<u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>9 in. wc.</u>	<u>9 in. wc.</u>	<u>10 min.</u>	<u>0</u>	<u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>First</u>	<u>Rego</u>	<u>06D2024 / LV4403TR9</u>	<u>u-c</u>
<u>Second</u>	<u>Rego</u>	<u>11E2024 / LV3403B4</u>	<u>down</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.

Metal building is back