

Route

1559 Lynch Rd.



HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

INVOICE
No. 10928



NAME	<u>Brody Williams</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>1559 Lynch Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-402-7152</u>	DATE COMPLETED	<u>7-17-25</u>
LOCATION		TERMS	

INSTRUCTIONS set 250 gallon tank, install tankless water heater, hook up generator, trench gas line in

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE1802 tankless water heater w/ isolation valves, serial # SH.4A-116054		1285 00
200	gallon of propane	2 99	598 00
1	Rago LV4403B66R second stage regulator		74 95
1	Rago LV3403B4 second stage regulator		59 95
88'	1/2" coated copper tubing	3 49	307 12
2	1/2" cut off valve	16 95	33 90
8	1/2" flare nut	1 60	12 80
1	Trencher rental		150 00
	all other gas fittings, thread sealant		48 36

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

set 250 gallon tank,

ran all gas line, trenched ditch for gas line, installed tankless water heater, hooked up generator, ran pressure check

TOTAL MATERIAL

2570 08

TOTAL TIME HOURS

LABOR

640 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

Daniel L. L.

SUBTOTAL

SALES TAX

205 61

TOTAL DUE

3415 69

X CUSTOMER'S SIGNATURE

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>250</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>1547359</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>200</u>	GALLONS OR READING:	AFTER 15 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

-GPGA rebate 200.00
AMOUNT
RECEIVED \$ 3,215.69

RECEIVED
BY

DATE

SERVICES RECEIVED
BY

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 7/17/25
 Name Brady Williams Company Sikes Propane, Inc.
 Address 1559 Lynch Rd Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-402-7152 (Home) _____

Appliance Check

Appliance	<u>water heater</u>	<u>Generator</u>				
Manufacturer	<u>Rinnai</u>	<u>Generac</u>				
Model #	<u>RE180e</u>	<u>G00721010</u>				
Serial #	<u>5H-4A-11</u> <u>6054</u>	<u>3016742089</u>				
BTU's	<u>180,000</u>	<u>355,000</u>				
Burner / Com. Chamber	<u>ok</u>	<u>ok</u>				
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>				
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>				
Venting System	<u>ok</u>	<u>ok</u>				
Age	<u>new</u>	<u>new</u>				
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>250</u>	<u>1547359</u>	<u>Quality Steel</u>	<u>2025</u>	<u>ok</u>	<u>new</u>	<u>09C22</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>130 psi</u>	<u>130 psi</u>	<u>10 min.</u>	<u>0</u> N
			Work Order <u>0</u> N

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9 in. wc.</u>	<u>9 in. wc.</u>	<u>10 min.</u>	<u>0</u> N
			Work Order <u>0</u> N

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>First</u>	<u>Rego</u>	<u>08D2024 / LV4403TR9</u>	<u>h-c</u>
<u>Second</u>	<u>Rego</u>	<u>12D2024 / LV4403B66R</u>	<u>down</u>
<u>Second</u>	<u>Rego</u>	<u>06C2022 / LV3403B4</u>	<u>down</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.