



INVOICE
No. 10939

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Down 2 Earth Trailers</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>Po. Box 509</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31515</u>	DATE PROMISED	
PHONE	<u>912-367-3007</u>	DATE COMPLETED	<u>7-18-25</u>
LOCATION	<u>@ Black Iron Product</u>	TERMS	

INSTRUCTIONS set 120 gallon tank, install tankless water heater

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE180a tankless water heater w/isolation valves, serial # SE.UA-059929		1285 00
100	gallon of propane	2 59	259 00
10	1/2" coated copper tubing	3 49	34 90
1	1/2" cut off valve		16 95
2	1/2" flare nut	1 60	3 20
1	1/2" swivel		3 99
1	1/2" x 3/4" female adapter		3 19
2	3/4" per. male adapter	2 89	5 78

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:	SERVICES PERFORMED <u>set 120 gallon tank, installed tankless water heater, ran pressure check</u>	TOTAL MATERIAL	1612 01
	1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 56 ☐		
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐			
	TOTAL TIME _____ HOURS	LABOR	260 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED BY <u>[Signature]</u>	SUBTOTAL	
X _____ CUSTOMER'S SIGNATURE		SALES TAX	
		TOTAL DUE	1872 01

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST		RECEIVED BY _____
		HIGH	LOW	
SIZE: <u>120</u>	SIZE: _____	START LOCK UP:	START LOCK UP:	DATE _____
S/N: <u>1527935</u>	S/N: _____	TANK OFF PRESSURE:	TANK OFF PRESSURE:	SERVICES RECEIVED BY _____
GALLONS OR READING: <u>100gal</u>	GALLONS OR READING: _____	AFTER 10 MINUTES:	AFTER 10 MINUTES:	
		PRESSURE AS LEFT:	PRESSURE AS LEFT:	

-GPGA rebate 200.00
AMOUNT
1672.01

GASCheck - Gas Appliance System Check

Account Name @ Black Iron Product Invoice Number _____ Date 7/18/25
 Name Down 2 Earth Trailers Company Sikes Propane, Inc.
 Address Po. Box 509 Call Taken By _____
 City Bakley State GA Zip 31515 Telephone (Cell) _____ (Home) 912-367-3007
Appliance Check

Appliance	<u>water heater</u>					
Manufacturer	<u>Rinnai</u>					
Model #	<u>RE180e</u>					
Serial #	<u>SE.4A-059</u> <u>929</u>					
BTU's	<u>180,000</u>					
Burner / Com. Chamber	<u>ok</u>					
Man. Shutoff / Sed. Trap	<u>installed</u>					
Control / Pilot Safety System	<u>ok</u>					
Venting System	<u>ok</u>					
Age	<u>new</u>					
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>1527935</u>	<u>Quality Steel</u>	<u>2024</u>	<u>ok</u>	<u>new</u>	<u>09D22</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>140 psi.</u>	<u>140 psi.</u>	<u>10 min.</u>	<u>0</u>	<u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>9 in. wc.</u>	<u>9 in. wc.</u>	<u>10 min.</u>	<u>0</u>	<u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection		
<u>Twin</u>	<u>Rego</u>	<u>09D2024 / LV404B39</u>	<u>n-c</u>		

Safety Information Supplied: _____

Comments: Please note all repairs and corrections made along with any recommended actions.