

Eddie Lugo Construction



HOME OWNED & OPERATED

INVOICE
No. 10915



P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Ken Heater</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>Po. Box 396</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Alma GA 31510</u>	DATE PROMISED	
PHONE	<u>1-703-232-6314</u>	DATE COMPLETED	<u>7-8-25</u>
LOCATION		TERMS	

INSTRUCTIONS change out cooktop

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
	<u>Thor cooktop</u>		
	<u>m # HRT3618ULP</u>		
	<u>5 # HRT3618ULP2402021</u>		

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐ 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	SERVICES PERFORMED <u>took out cooktop</u> <u>that was not working properly,</u> <u>installed new cooktop, ran pressure</u> <u>check, lit & checked out</u>	TOTAL MATERIAL	
	TOTAL TIME _____ HOURS	LABOR	<u>180.00</u>

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME. X _____ CUSTOMER'S SIGNATURE	SERVICES PERFORMED BY <u>[Signature]</u>	SUBTOTAL SALES TAX TOTAL DUE <u>180.00</u>
---	--	--

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				GRPA rebate - <u>50.00</u> AMOUNT RECEIVED \$ <u>130.00</u>
INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST		RECEIVED BY _____
		HIGH	LOW	
SIZE:	SIZE:	START LOCK UP:	START LOCK UP:	DATE _____
S/N:	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:	SERVICES RECEIVED BY _____
GALLONS OR READING:	GALLONS OR READING:	AFTER 10 MINUTES PRESSURE AS LEFT:	AFTER 10 MINUTES PRESSURE AS LEFT:	

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 4 22 25
 Name Ken Heaton Company Sikes Propane, Inc.
 Address Po. Box 396 Call Taken By _____
 City Alma State GA Zip 31510 Telephone (Cell) 703-232-6314 (Home) _____

Appliance Check

Appliance	water heater	water heater	gas loss	gas loss	cooktop	gas light	other
Manufacturer	Rinnai	Rinnai	Peterson	Empire	Thor	MHP	55207
Model #	RE199a	RE180	G10-28/30-15(M)P	DVCT36CB P95P-3	HRT3618K	WK-005	56756
Serial #	RC.4A-04 7785	RE.4A-06 2575	2057294	231819877	HRT3618K22 12068	56755	56761
BTU's	199,000	180,000	37,000	40,000	87,000	1960	56757
Burner - Com. Chamber	ok	ok	ok	ok	ok	ok	56759
Man. Shutoff - Sed. Trap	installed	installed	installed	installed	installed	installed	56762
Control - Pilot Safety System	ok	ok	ok	ok	ok	ok	56758
Venting System	ok	ok	ok	ok	ok	ok	56763
Combustion Air	new	new	new	new	new	new	56754
Flue Gas Out of Service Or Operation			30"	36"		(X11)	56760

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
500	1492199	Quality Steel	2023	ok	ok	12D22	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
110 psi.	110 psi.	10 min.	0
			0

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
9 in. wc.	9 in. wc.	10 min.	0
			0

Piping Check

Material	Size	Cover Protection
poly pipe	1"	ok
coated copper	1/2" + 3/8"	ok

Regulator Check

Type	Manufacturer	Date Model	Vent Pasion Protection
first	Rego	06D2024 / LV4403TR9	H-C
second	Rego	06E2022 / LV4403B66R	down
second	Rego	09C2021 / LV4403B66	down
second	Rego	04C2024 / LV4403B66R	down
second	Rego	10D2023 / LV3403B4	down
second	Rego	10D2023 / LV3403B4	down

(X3)

Comments: Please note all repairs and corrections made along with any recommended actions