

INVOICE

FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD, GA 31750

(229) 426-5400

TO: TRISTON WALKER
271 LIVE OAK RD
FITZGERALD, GA 31750

INVOICE NO: 54059
DATE: 7/23/25

CUSTOMER NO: 3638/3717

TYPE: RR - Residential Irwin Co

QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED PRICE
1.00	MDSE - Appliances SERIAL # TD UA 061675 Inventory item selected for charge code: AP-60000163021 Quantity: 1.00 351-RE199EP	1,305.76	1,305.76
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163011 Quantity: 1.00 PIPE COV ENCL 4 R75L	191.70	191.70
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163032 Quantity: 1.00 PLUMBING INSTALLATION KIT	69.60	69.60
1.00	Sales Tax	125.36	125.36
1.00	Tank Lease	60.00	60.00

TOTAL DUE: \$1,752.42

PLEASE DETACH AND SEND THIS COPY WITH REMITTANCE

DATE: 7/23/25 DUE DATE: 8/04/25
CUSTOMER NO: 3638/3717

NAME: WALKER, TRISTON
TYPE: RR - Residential Irwin Co

REMIT AND MAKE CHECK PAYABLE TO:
FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD GA 31750

INVOICE NO: 54059
TERMS: NET 10 DAYS

AMOUNT:

GA \$1,752.42
Rebate - 200.00
1,552.42

Account Number 3638

Name Triston Walker

Address 271 Live Oak Rd

Call Date: 7/23/25 Date Requested: 7/24/25

Instructions: set tank / inspect water heater

Telephone Office: _____ Home: _____

Appliance Check Item:	Central Heating 1	Space Heater 2	Water Heater 3	Range 4	Clothes Dryer 5	6	7
Manufacturer			Rinnai				
Model No.			RE199e				
Serial No.			TD-VA-061675				
Location			Exterior				
BTU	000	000	199 000	N/A	N/A	000	000
Age			New				
Manual Shutoff (Installed/Existing)			Installed				
Venting			gd				

TANK/CYLINDER 120 129X

SIZE	SERIAL NUMBER	MFR.	MFR. DATE	Last Test Date	Location	Tank Cond.	Paint	Pigtail	Fittings	Gauge	Relief Valve			Fittings Leak Test	
											Cond.	Date	Cap		
120	2470285	working tank	2023	7/20/25	Exterior	New	New	New	New	New	New	New	—	New	5 min

PIPING/REGULATOR OPERATION/CONDITION

PIPING/REGULATOR OPERATION/CONDITION

SINGLE STAGE	PIPING		REGULATOR DATE CODE	REGULATOR CONDITION	MFR.	MODEL	REG. VENT POSITION	HOW PROTECTED	FLOW PRESSURE
	MATERIAL	SIZE							
TWO STAGE	1ST	Copper 1/2	9/1/25	New	Rego	LV40434	Level 1	Done	11 IN. WC
	2ND	Copper 1/2							PSIG
									IN. WC

SYSTEM LEAK TEST

SINGLE STAGE	Start Pressure	End Pressure	Time Held	System OK
	(Inches W.C.)	(Inches W.C.)		
	11	11	5 min	OK
	(PSIG)	(PSIG)		
TWO STAGE				
1ST	(Inches W.C.)	(Inches W.C.)		
2ND				

Comments: _____

This inspection covers (propane/LP-Gas) items and equipment visible and accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal working of sealed equipment, or structural components, and cannot be construed to cover future defects or unforeseen happenings.

Reference Invoice No. WF0537043 Date 7/24/25
(Mo. Day Yr.)

Chris Woods
(Please Print)

Certify that I have completed the System Check as prescribed

Performed Odor Test ☒ Yes

Performed Pressure Test ☒ Yes
Left Consumer Safety Info ☒ Yes

- Know how to turn off gas in case of emergency.
- Have smelled propane and can detect its odor.
- Have received the Consumer Safety Information.
- Had gas system deficiencies and / or corrections, if any, clearly explained to me.
- Am satisfied with the service work performed.