



congerlpgas.com

121523

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Marcus Fletcher Construction RT# _____ RT. SEQ. _____ ACCT # 02-18588 DATE 6-25-25 INT JB

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 106 Creekside Drive APT/LOT NO. _____

CITY Sylvester STATE GA ZIP CODE 31791

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: _____

cell # _____

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

Install tankless106 Creekside

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
<u>TS</u>	<u>120</u>	<u>2594784</u>	<u>10 gallons</u>		MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>Rinnai tankless</u>	<u>RX180iN</u>	<u>SHBA133692</u>	<u>(M/H)</u>	<u>1699.95</u>
	<u>Rinnai drip pan</u>				<u>64.95</u>
	<u>Vent</u>				<u>95.95</u>
<u>52'</u>	<u>3/4" trace</u>			<u>7.95</u>	<u>413.40</u>
	<u>Sediment trap with auto valve</u>				<u>44.95</u>
<u>2</u>	<u>trace ends</u>			<u>44.95</u>	<u>89.90</u>
<u>2</u>	<u>nail guards</u>			<u>7.95</u>	<u>15.90</u>
	<u>B46R regulator</u>				<u>29.95</u>
				<u>(MP)</u>	<u>840.70</u>

WORK PERFORMED: <u>Installed tankless.</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE	
<u>Piped up house</u>	MAKE: <u>Rego</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED		
	DATE CODE: <u>05C2025</u>	VENT: <u>Down</u>	TANK RENT	<u>01</u>	<u>39.99</u>
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE					<u>CF</u> <u>14.95</u>
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:			SALES TAX		<u>136.00</u> <u>6726</u>
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>	LEAK AND PRESSURE TEST		%		<u>1.20</u> <u>749</u>
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	HIGH: 1st Stage	2nd Stage	LOW		<u>3.20</u>
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	START LOCK-UP: <u>9.3</u> PSI		START LOCK-UP: <u>13.1</u> W.C.	LABOR	<u>720.00</u>
	TANK OFF: PRESSURE <u>6.0</u> PSI		TANK OFF: PRESSURE <u>9.0</u> W.C.		<u>GR</u> <u>(200.00)</u>
	AFTER 10 MINUTES: <u>6.0</u> PSI		AFTER 10 MINUTES: <u>9.0</u> W.C.		
	PRESSURE AS LEFT: <u>9.0</u> PSI		PRESSURE AS LEFT: <u>11.0</u> W.C.		<u>3424.38</u>
X _____ CUSTOMER SIGNATURE			PIPING PRESSURE TEST		INV. TOTAL
			START <u>6.0</u> PSIG	FINISH <u>6.0</u> PSIG	AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Jay Justin
SERVICE REP. SIGNATURE

6-9-25
DATE

X

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY