



congerlpgas.com

INVOICE / WORK ORDER NO.

120863

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Marcus Fletcher Construction RT# _____ RT. SEQ. _____ ACCT # 02-18588 DATE 6-25-25 INT JS

MAILING ADDRESS 129 N Main St. Syl CO. _____ CITY _____

ADDRESS 255 Marsh Rd APT/LOT NO. _____

CITY Ade Run STATE _____ ZIP CODE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

(Matt Tillery)

DIRECTIONS: Install tankless

255 Marsh Rd

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: _____

cell # _____

PAY BILL ONLINE @congerlpgas.com

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
FS	120	2594697	10	Long	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	R-main tankless	RE180e	TBWA-022649	(VHT)	1199.95
	Sediment trap with cutoff valve				44.95
36'	3/4" gas pipe			7.95	286.20
2	3/4" gas ends			44.95	89.90
5	striker plates			7.95	39.75
	Cover kit				119.95
	LV4403B46R regulator				79.95
	1/2" cutoff valve				19.95
2	3/8" flare nuts			(MP)	1724.25

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
Installed tankless.	MAKE: <u>Rego</u> MODEL: <u>TR9</u>	PARTS/MAT. USED	(MS)
Piped up house	DATE CODE: <u>10C2024</u> VENT: <u>Down</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST				SALES TAX				57.94 90 4.77 1.20	
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐		HIGH:		1st Stage	2nd Stage	LOW		_____ %			
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐		START LOCK-UP:		9.2	PSI		PSI	START LOCK-UP:		13.2	W.C.
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE		6.0	PSI		PSI	TANK OFF: PRESSURE		9.0	W.C.
		AFTER 10 MINUTES:		6.0	PSI		PSI	AFTER 10 MINUTES:		9.0	W.C.
		PRESSURE AS LEFT:		9.0	PSI		PSI	PRESSURE AS LEFT:		11.0	W.C.
X _____		PIPING PRESSURE TEST				INV. TOTAL		2228.72			
CUSTOMER SIGNATURE		START		6.0	PSIG	FINISH		6.0	PSIG	AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY