

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Sara Beth UTZ RT# _____ RT. SEQ. _____ ACCT # 2-23517 DATE 7-18-2025 INT JS

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 135 Joyce Rd APT/LOT NO. _____

CITY Sylvestre STATE GA ZIP CODE 31791

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

DIRECTIONS: Set tank, installed water heater

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____

HOME PH _____ RENT _____

WORK PH _____ CREDIT _____

LITE PILOT PC

EMPLOYER _____

DR. _____ USE _____ LEASE _____

email:

cell # 229-344-3867

PAY BILL ONLINE @congerlpgas.com

[illegible]

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	RE180c			(WH)	1199.95
171	3/4 trap			7.95	15.90
2	3/4 straight fittings			44.95	89.90
	Settlement trap w/cutoff				44.95
	Plumbing				74.95
				(MP)	225.70

WORK PERFORMED:	Set tank, installed	REGULATION INFORMATION		APPLIANCES/ EQUIP. SOLD	MS CODE	24:34
Water heater	MAKE: rego	MODEL: B9	PARTS/MAT. USED	01	38:49	
	DATE CODE: 04A2022	VENT: Down	TANK RENT	TR	10:00	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

LEAK AND PRESSURE TEST

SALES TAX _____ %

- 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐
- 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP:	PSI	PSI	START LOCK-UP: 13.2 W.C.
TANK OFF: PRESSURE	PSI	PSI	TANK OFF: PRESSURE 9.0 W.C.
AFTER 10 MINUTES:	PSI	PSI	AFTER 10 MINUTES: 9.0 W.C.
PRESSURE AS LEFT:	PSI	PSI	PRESSURE AS LEFT: 11.0 W.C.

LABOR	180.00
-------	--------

	AP	(260 : 88)
--	----	------------

1.	OK	(200)	55
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			
11.			
12.			
13.			
14.			
15.			
16.			
17.			
18.			
19.			
20.			
21.			
22.			
23.			
24.			
25.			
26.			
27.			
28.			
29.			
30.			
31.			
32.			
33.			
34.			
35.			
36.			
37.			
38.			
39.			
40.			
41.			
42.			
43.			
44.			
45.			
46.			
47.			
48.			
49.			
50.			
51.			
52.			
53.			
54.			
55.			
56.			
57.			
58.			
59.			
60.			
61.			
62.			
63.			
64.			
65.			
66.			
67.			
68.			
69.			
70.			
71.			
72.			
73.			
74.			
75.			
76.			
77.			
78.			
79.			
80.			
81.			
82.			
83.			
84.			
85.			
86.			
87.			
88.			
89.			
90.			
91.			
92.			
93.			
94.			
95.			
96.			
97.			
98.			
99.			
100.			

9.			
----	--	--	--

[illegible]

| x

CUSTOMER SIGNATURE

PIPING PRESSURE TEST

INV. TOTAL

START	9.0	W.C	PSIG	FINISH	9.0	W.C	PSIG
-------	-----	-----	------	--------	-----	-----	------

AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Justin L. Davis
SERVICE REP. SIGNATURE

7-18-2025
DATE

2

CUSTOMER SIGNATURE _____