CONGER FUELING LIFE LP GAS

congerlpgas.com

INVOICE / WORK ORDER NO. 117283

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574
306 S. Main St. Sylvester, GA 31791 (229) 776-7336
604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722
3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942
2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

NAME Ben Fairbrother RT# ____ RT. SEQ. ____ ACCT # 03-22788 DATE 8-11-25 INT ____

MAILING ADDRESS ____ CO. ____ CITY ____

ADDRESS 693 West Shore Dr. APT/LOT NO. ____

CITY Ochlocknee STATE GA ZIP CODE 31773

NEW CUSTOMER INFORMATION
S.S. NO. ____ DELV ____
HOME PH ____ RENT ____
WORK PH ____ CREDIT ____
LITE PILOT ____ PC ____
EMPLOYER ____
DR. ____ USE ____ LEASE ____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED ____

email: b.fairbrother2@gmail.com
cell # (850) 443-1252

PAY BILL ONLINE @congerlpgas.com

Run lines for (2) TWH and Cooktop. Set 120 gallon tank.

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
TS	120	1528981							
		10 * 3.849 =		38.49 +	444 +	16.95 =		59	88

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rinnai	RX199iSK	BA-172934		1799 95
60	ft. 3/4" trac				471 00
15	ft. 1/2" Copper				74 25
6	1/2" flare nut				17 70
2	3/4" Maxitrol				179 90
	Black Iron				70 00
1	Rego LV4403B4612				79 95
1	Rego LV4403X4612			933	99 95
1	Rinnai	RX199i	SK.BA.172933		1799 95

WORK PERFOMED: Hung (2) TWH. Set 120 gallon tank. Converted Stoc. Has. Check, ok no leaks.

REGULATION INFORMATION
MAKE: Rego MODEL: LV4404X9
DATE CODE 01/25 VENT: down

APPLIANCES/ EQUIP. SOLD	CODE	
	WH	3599 90
PARTS/MAT. USED	MP	1303 60
TANK RENT	MS	121 40
	CE	14 95
SALES TAX ____ %	104.29	287.99
	9.71	1,336.80
LABOR	LB	720 00
	TR	10 00
	GPC	400 00
INV. TOTAL		5835.88
AMOUNT RECEIVED	GPC	400 00
		6235.88

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X ____ CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST

HIGH:	1st Stage	2nd Stage	LOW	
START LOCK-UP:	PSI	PSI	START LOCK-UP:	12 W.C.
TANK OFF: PRESSURE	PSI	PSI	TANK OFF: PRESSURE	9 W.C.
AFTER 10 MINUTES:	PSI	PSI	AFTER 10 MINUTES:	9 W.C.
PRESSURE AS LEFT:	PSI	PSI	PRESSURE AS LEFT:	12 W.C.

PIPING PRESSURE TEST
START ____ PSIG FINISH ____ PSIG

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE ____ DATE 8-11-25 X ____ CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY