

121488

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Ragan Paramore RT# _____ RT. SEQ. _____ ACCT # 2-23802 DATE 8-1-25 INT JS

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 1753 Cant Mill Road APT/LOT NO. _____

CITY Doerun STATE GA ZIP CODE 31744

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____

HOME PH _____ RENT _____

WORK PH _____ CREDIT _____

LITE PILOT _____ PC _____

EMPLOYER _____

DR. _____ USE _____ LEASE _____

email:

cell # 227-881-5632

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: Set tank installed w/h

[illegible]

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	Rel80c	Rel80c	TDUA-058697		1199.95
18'	3/8 copper			3.95	71.10
	Settlement trap w/cutoff				44.95
1	3/8-1/2 M.P				3.95
2	3/8 flare nuts			1.95	3.90
	B46R regulator				79.95
	Brackets				34.95
				(M.P)	238.80

WORK PERFORMED:	Set tank, installed	REGULATION INFORMATION		APPLIANCES/ EQUIP. SOLD	CODE	25	13
W/h		MAKE: rego	MODEL: TA9	PARTS/MAT. USED	(01)	38	49
		DATE CODE: 05D1024	VENT: Down	TANK RENT	BR	(200	00)
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE					PF	14	95

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST				SALES TAX			96.00 1.20 19.10 2013.08
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐		HIGH:	1st Stage	2nd Stage	LOW	_____ %			
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐		START LOCK-UP:	9.2 PSI	PSI	START LOCK-UP:	12.7 W.C.	LABOR		186.00
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE	6.0 PSI	PSI	TANK OFF: PRESSURE	9.0 W.C.	TR		10.80
		AFTER 10 MINUTES:	6.0 PSI	PSI	AFTER 10 MINUTES:	9.0 W.C.			
		PRESSURE AS LEFT:	9.2 PSI	PSI	PRESSURE AS LEFT:	11.0 W.C.			
X _____		PIPING PRESSURE TEST				INV. TOTAL			1629.51
CUSTOMER SIGNATURE		START	6.0 PSIG	FINISH	6.0 PSIG	AMOUNT RECEIVED			

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Justin + Jamil
SERVICE REP. SIGNATURE

7-24-2025
DATE

✱

CUSTOMER SIGNATURE

WHITE/FILE COPY: YELLOW/CUSTOMER COPY: PINK/POSTING COPY