



congerlpgas.com

INVOICE / WORK ORDER NO.

121301

146 S. Ridge Ave.  
Tifton, GA 31794  
(229) 386-5574

306 S. Main St.  
Sylvester, GA 31791  
(229) 776-7336

604-B N. Broadfoot Blvd.  
Vidalia, GA 30474  
(912) 537-8722

3117 Veterans Parkway S.  
Moultrie, GA 31788  
(229) 985-6942

2310-B Highway 84 W  
Valdosta, GA 31602  
(229) 469-4250

NAME Rusty Lynne Irvin RT# \_\_\_\_\_ RT. SEQ. \_\_\_\_\_ ACCT # 01-05095 DATE 8-4-25 INT \_\_\_\_\_

MAILING ADDRESS 255 Rusty Nail Rd CO. \_\_\_\_\_ CITY \_\_\_\_\_

ADDRESS \_\_\_\_\_ APT/LOT NO. \_\_\_\_\_

CITY Ashburn STATE GA ZIP CODE 31714

NEW CUSTOMER INFORMATION	
S.S. NO. _____	DELV _____
HOME PH _____	RENT _____
WORK PH _____	CREDIT _____
LITE PILOT _____	PC _____
EMPLOYER _____	
DR. _____	USE _____ LEASE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED \_\_\_\_\_

email: \_\_\_\_\_

cell # 567-3002

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: Rusty Nail Rd

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>Rinnai</u>	<u>RE180c</u>	<u>TDUA-058693</u>		<u>1199.95</u>
	<u>SWAP OUT</u>				

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>Replaced water heater</u>	MAKE: <u>Rcgo</u> MODEL: <u>LV3403TR9</u>	PARTS/MAT. USED	(GR)
	DATE CODE: <u>1202021</u> VENT: <u>Down</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:	LEAK AND PRESSURE TEST	SALES TAX
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>	HIGH: 1st Stage 2nd Stage LOW	_____ %
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/>	START LOCK-UP: 9.2 PSI PSI START LOCK-UP: 12.9 W.C. LABOR	
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: PRESSURE 6.0 PSI PSI TANK OFF: PRESSURE 9.0 W.C.	
	AFTER 10 MINUTES: 4.0 PSI PSI AFTER 10 MINUTES: 9.0 W.C.	
	PRESSURE AS LEFT: 9.0 PSI PSI PRESSURE AS LEFT: 4.0 W.C.	
X _____	PIPING PRESSURE TEST	INV. TOTAL
CUSTOMER SIGNATURE	START 6.0 PSIG FINISH 6.0 PSIG	AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY