



INVOICE
No. 10948

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Hoyt Altman</u>	ACCOUNT NO.	_____
MAIL ADDRESS	<u>495 Cannon Rd.</u>	DATE ORDERED	_____
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	_____
PHONE	<u>912-240-9817</u>	DATE COMPLETED	<u>8-6-25</u>
LOCATION	_____	TERMS	_____

INSTRUCTIONS install tankless water heater

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RL75e tankless water heater w/ isolation valves & T-pad, serial # PC-CA-0431 33		1285 00
1	1/2" cut off valve		16 95
1	1/2" x 3/4" female adaptor		3 99
2	3/4" shack bite coupling	10 99	21 98
1	1/2" swivel		3 99
2	3/4" per 90° elbow	2 89	5 78

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	SERVICES PERFORMED <u>took out old damaged water heater, installed new tankless water heater, ran pressure check, lit & checked out appliances</u>	TOTAL MATERIAL	1337 69
	TOTAL TIME _____ HOURS	LABOR	300 00
THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED BY <u>Daniel Sikes</u>	SUBTOTAL	
X _____ CUSTOMER'S SIGNATURE		SALES TAX	107 02
		TOTAL DUE	1744 71

-GPA rebate 400.00
AMOUNT \$ 1344.71

INSTALLATION OR TURN ON		REMOVAL OR TURN OFF		LEAK AND PRESSURE TEST	
SIZE:	SIZE:	HIGH	LOW	START LOCK UP:	START LOCK UP:
		TANK OFF PRESSURE:	TANK OFF PRESSURE:		
S/N:	S/N:	AFTER 10 MINUTES:	AFTER 10 MINUTES:		
GALLONS OR READING:	GALLONS OR READING:	PRESSURE AS LEFT:	PRESSURE AS LEFT:		

RECEIVED BY _____
DATE _____
SERVICES RECEIVED BY _____

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 8/6/25
 Name Hoyt Altman Company Sikes Propane, Inc.
 Address 495 Cannon Rd Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-240-9817 (Home) _____

Appliance Check

Appliance	water heater	Range	clothes dryer	gas logs		
Manufacturer	Rinnai	Kitchen Aid	Maytag	Peterson		
Model #	RL75e	KGCK306V	LDG312	Real-Fyre		
Serial #	PC-CA-0 43133	SS01 D01326112	432827 VX	G10-24730 -15CM)P 1345055		
BTU's	180,000	N/A	22,000	37,000		
Burner / Com. Chamber	ok	ok	ok	ok		
Man. Shutoff / Sed. Trap	existing	existing	existing	existing		
Control / Pilot Safety System	ok	ok	ok	ok		
Venting System	ok	ok	ok	ok		
Age	new	15yrs.	31yrs.	8yrs.		
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
250	148796	Delta	1976	ok	ok	12-76	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
140psi.	140psi.	10min.	<input checked="" type="radio"/> N	<input checked="" type="radio"/> N

Piping Check

Materials	Size	Cover / Protection
copper	5" 1/2" 3" 1/8", 3/8"	ok

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
9in.wc.	9in.wc.	10min.	<input checked="" type="radio"/> N	<input checked="" type="radio"/> N

Regulator Check

Type	Manufacturer	Date / Model	Vent Position/ Protection
First	Rego	4-90 / 4403TR9	u-c
Second	Rego	03B08 / LV4403B4	down
Second	Rego	09C2021 / LV4403TR66	down

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.