

# BARFIELD GAS COMPANY



POST OFFICE BOX 990  
312 OLD QUITMAN HWY.  
PHONE 229-896-4828  
ADEL, GEORGIA 31620

POST OFFICE BOX 308  
RAILROAD STREET  
PHONE 229-532-2925  
ALAPAHA, GEORGIA 31622

INVOICE NO. 56877

DATE 5-8-25

NAME South GA. Builders  
ADDRESS @4855 McConnell Bridge Rd  
CITY, STATE, ZIP Adel  
PHONE \_\_\_\_\_

QUANTITY	DESCRIPTION	UNIT PRICE	AMOUNT
	Run Gas line for stove & Hang water heater		
1	Rinnai RE190ep ser # TC. UA-040280		1250.00
72#	1/2 Trackpipe		306.00
1	1/2 Appliance Box		89.95
1	1/2 Trackpipe straight w/Flange		39.95
1	pressure guage		15.95
2	short nail plate		5.00
2	long nail plate		10.50
2	double nail plate		20.00
1	3/4 Catoff		19.95
1	1/2 BI Tee		5.50
1	1/2 x 3/4 BI Bushing		2.00
1	5/8 x 24" flexline		34.95

**DESCRIBE WORK PERFORMED:**

Cut sheetrock & ran line for stove & did pressure test.  
6-16-25 Hang water heater, connected water heater to house

**SYSTEM LEAK TEST**

SINGLE STAGE	START PRESSURE	END PRESSURE	TIME HELD	SYSTEM OK
	(INCHES W.C.)	(INCHES W.C.)		
TWO STAGE	1st (PSIG)	(PSIG)		
	2nd (INCHES W.C.)	(INCHES W.C.)		

TOTAL MATERIALS	1789.75
STATE AND LOCAL SALES TAX	143.18
Rinnai Rebate	-200.00
LABOR	300.00
<b>TOTAL</b>	<b>2032.93</b>

THIS IS YOUR INVOICE, PLEASE PAY THIS AMOUNT → →

Date Completed 6-16-25  
Barfield Gas Co. Rep. Les. Cobb

Terms of this agreement are understood and accepted. Services received by:  
Customer Signature \_\_\_\_\_

## Required Safety inspections

This page must be completed and included with the rebate application. Failure to include this page will automatically disqualify the customer for the safety rebate.

Test	Beginning Pressure	Ending Pressure	Test Duration
Pressure test (when required by code or local authority)	12.8 IWC	12.8 IWC	3 min
Leak test	12.8 IWC	12.8 IWC	3 min
Flow test	X	12.2 IWC	X
Lock-up pressure	X	.9 IWC	3 min

Technician's Certification: I, Caleb Havnage, certify that the above tests were performed and the results were recorded correctly.

Date of Inspection: 8-19-25

Propane Dealer's Signature: Mikes Party

This paperwork must be submitted to the GA Propane Commission within 30 days of appliance inspection date to receive rebate.

### *Disclaimer:*

*The propane dealer seeking a rebate must submit a full and complete Application form. Submission of the Application form constitutes a representation on the part of the participating propane dealer that the work shown on the form has actually been completed. A safety inspection must be performed by the participating propane dealer after the installation of each new qualifying appliance(s) and the result of that inspection must be documented on the Application form. The safety inspection for qualifying appliance installations must, at a minimum, include the following: 1) a leak test; 2) a pressure test if required by applicable laws, rules and regulations; and 3) a flow and lock up test on the regulator[s]. The propane dealer agrees to comply with all laws, rules and regulations governing the installation of the qualifying appliance and with the manufacturer's installation instructions. The Southeast Propane Alliance and GA Propane Commission assumes no responsibility whatsoever for the installation, inspection, or testing of the qualifying appliance(s) or any associated gas system and, by issuing a rebate, makes no representation, warranty or guarantee regarding the qualifying appliance(s) or the associated gas system. The Southeast Propane Alliance and GA Propane Commission disclaims any liability for any personal injury, property damage, business losses or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly arising from the installation of the qualifying appliance(s).*

Please submit your 2-page rebate form and receipt(s) to:

Mail: GA Propane Commission  
5109 Hollyridge Dr.  
Raleigh, NC 27612

Fax: 919 781-7481

Email: [info@gapropanerebates.com](mailto:info@gapropanerebates.com)