

BARFIELD GAS COMPANY



POST OFFICE BOX 990
312 OLD QUITMAN HWY.
PHONE 229-896-4828
ADEL, GEORGIA 31620

POST OFFICE BOX 308
RAILROAD STREET
PHONE 229-532-2925
ALAPAHA, GEORGIA 31622

INVOICE NO. 56983

DATE 7-3-25

NAME Terry Tucker
ADDRESS 1480 Hwy 41
CITY, STATE, ZIP Sparks Ga
PHONE 507-8976

QUANTITY	DESCRIPTION	UNIT PRICE	AMOUNT
1	Generac 22KW Generator Mod G00764311 SN#3613778813 Engr. IDENT NO A0000288775 eng Ser. NO. 3613139596		5800.00
1	250 gal Ag/Ug Tank and Bag 57158 - serial #		2100.00
1	Binnel RE199ePTankless water heater, Ser#TE.075796 Cover		1450.00 150.00
1	Superior WCT 3042 WST 42" Insulated Vented Box Sea		1679.27
3	48" 80M Vent Pipe & RLT-80M Round Top		
1	BK Rotary Fan Manual Control/Variable		
		Mini Exhauster	250.00

DESCRIBE WORK PERFORMED:

Buried tank

SYSTEM LEAK TEST

SINGLE STAGE	START PRESSURE	END PRESSURE	TIME HELD	SYSTEM OK
	(INCHES W.C.)	(INCHES W.C.)		
TWO STAGE	1st (PSIG)	(PSIG)		
	2nd (INCHES W.C.)	(INCHES W.C.)		

TOTAL MATERIALS	11,429.27
STATE AND LOCAL SALES TAX	914.00
Binnel Rebate	-200.00
LABOR	200.00
TOTAL	12,343.61

THIS IS YOUR INVOICE, PLEASE PAY THIS AMOUNT → →

Date Completed 7-10-25
Barfield Gas Co. Rep. Lee Josh

Terms of this agreement are understood and accepted. Services received by:
Customer Signature _____

2.11.9

Required Safety inspections

This page must be completed and included with the rebate application. Failure to include this page will automatically disqualify the customer for the safety rebate.

Test	Beginning Pressure	Ending Pressure	Test Duration
Pressure test (when required by code or local authority)	13.5 IWC	13.5 IWC	3 min
Leak test	13.5 IWC	13.5 IWC	3 min
Flow test	X	12.9 IWC	X
Lock-up pressure	X	8 IWC	5 min

Technician's Certification: I, Caleb Harnage, certify that the above tests were performed and the results were recorded correctly.

Date of Inspection: 8-15-25

Propane Dealer's Signature: Michael Davis

This paperwork must be submitted to the GA Propane Commission within 30 days of appliance inspection date to receive rebate.

Disclaimer:

The propane dealer seeking a rebate must submit a full and complete Application form. Submission of the Application form constitutes a representation on the part of the participating propane dealer that the work shown on the form has actually been completed. A safety inspection must be performed by the participating propane dealer after the installation of each new qualifying appliance(s) and the result of that inspection must be documented on the Application form. The safety inspection for qualifying appliance installations must, at a minimum, include the following: 1) a leak test; 2) a pressure test if required by applicable laws, rules and regulations; and 3) a flow and lock up test on the regulator[s]. The propane dealer agrees to comply with all laws, rules and regulations governing the installation of the qualifying appliance and with the manufacturer's installation instructions. The Southeast Propane Alliance and GA Propane Commission assumes no responsibility whatsoever for the installation, inspection, or testing of the qualifying appliance(s) or any associated gas system and, by issuing a rebate, makes no representation, warranty or guarantee regarding the qualifying appliance(s) or the associated gas system. The Southeast Propane Alliance and GA Propane Commission disclaims any liability for any personal injury, property damage, business losses or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly arising from the installation of the qualifying appliance(s).

Please submit your 2-page rebate form and receipt(s) to:

Mail: GA Propane Commission
5109 Hollyridge Dr.
Raleigh, NC 27612

Fax: 919 781-7481

Email: info@gapropanerebates.com