



congerlpgas.com

INVOICE / WORK ORDER NO.

114587

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

NAME Garrett Homes - Bodie Myer RT. SEQ. _____ ACCT # 7-11962 DATE 8-11-25 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 313 Wiggins Rd. APT/LOT NO. _____

CITY Lynn STATE GA ZIP CODE _____

NEW CUSTOMER INFORMATION	
S.S. NO. _____	DELV _____
HOME PH _____	RENT _____
WORK PH _____	CREDIT _____
LITE PILOT _____	PC _____
EMPLOYER _____	
DR. _____	USE _____ LEASE _____

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

TANK SET, run lines for generator.
Gas check exterior lines only

email: _____
cell # 407-947-3973
PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: _____

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
TS	500	1522446	0	On Site					

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	AGUG 500 Tank		1522446	4700.00	4700.00
1	1716 Anode Bag			299.95	299.95
1	Rinnai water heater	Rx180in	SL13A-196779	1699.95	1699.95
1	Presto Tap pigtail			29.95	29.95
1	TR96 Regulator			79.95	79.95
1	446R Regulator			74.95	74.95
1	BobR Regulator			69.95	69.95
150	3/4 Poly			0.95	142.50
3	3/4 transitions			89.90	269.70

WORK PERFORMED: <u>Tank set, ran all lines</u>	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD CODE	4999.95
<u>Gas check exterior lines only</u>	MAKE: <u>Rego</u> MODEL: <u>TR96</u>	PARTS/MAT. USED	1075.40 (86.03)
	DATE CODE: <u>10/2021</u> VENT: <u>Down</u>	TANK RENT	1699.95 (136)

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX _____ %	LABOR
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>	HIGH: 1st Stage 2nd Stage LOW				
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	START LOCK-UP: 10 PSI PSI	START LOCK-UP: _____ W.C.			540.00
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: PRESSURE 6 PSI PSI	TANK OFF: PRESSURE _____ W.C.	<u>Trucker</u>		150.00 (12.00)
	AFTER 10 MINUTES: 6 PSI PSI	AFTER 10 MINUTES: _____ W.C.	<u>MS</u>		96.92 (7.70)
	PRESSURE AS LEFT: 10 PSI PSI	PRESSURE AS LEFT: _____ W.C.		<u>OR</u>	(200.00)
CUSTOMER SIGNATURE _____	PIPING PRESSURE TEST		INV. TOTAL	9220.15	
	START PSIG	FINISH PSIG	AMOUNT RECEIVED		

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE _____ DATE 8/11/25 CUSTOMER SIGNATURE _____