



congerlpgas.com

INVOICE / WORK ORDER NO.

117104

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

NAME Morgan Grouver RT# RT. SEQ. ACCT # 03-23666 DATE 8-19-25 INT DB

MAILING ADDRESS 5319 N Jefferson St CO. CITY

ADDRESS Kiss away plantation APT/LOT NO.

CITY Monticello STATE FL ZIP CODE 32344

NEW CUSTOMER INFORMATION S.S. NO. DELV HOME PH RENT WORK PH CREDIT LITE PILOT PC EMPLOYER DR. USE LEASE

email: mgrouver@congerlpgas.com cell # 229-300-3055

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: CASH CHARGE DATE PROMISED

DIRECTIONS:

Table with columns: TANK PICKUP/SET, TANK SIZE, SERIAL #, TANK %, TANK DESTINATION, DOT PERMANENTLY INSTALLED CONTAINERS (MANUFACTURED DATE, LAST TEST DATE, SIZE, SERIAL #, % FULL)

Table with columns: QTY, APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED, MODEL #, SERIAL NUMBER, UNIT PRICE, SALES AMOUNT

WORK PERFORMED: Hooked up outdoor K.ichang Hung water Heater. REGULATION INFORMATION MAKE: Rego MODEL: B46t. DATE CODE: 9-24 VENT: Down.

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: LEAK AND PRESSURE TEST. HIGH: 1st Stage 2nd Stage LOW. START LOCK-UP: PSI PSI START LOCK-UP: 12.2 W.C. LABOR. TANK OFF: PRESSURE PSI PSI TANK OFF: PRESSURE 9 W.C. AFTER 10 MINUTES: PSI PSI AFTER 10 MINUTES: 9 W.C. PRESSURE AS LEFT: PSI PSI PRESSURE AS LEFT: 11.7 W.C. INV. TOTAL 1560.30 AMOUNT RECEIVED 200.00

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE. SERVICE REP. SIGNATURE DATE 8/19/2025 CUSTOMER SIGNATURE 1760.30