



congerlpgas.com

INVOICE / WORK ORDER NO.

117191

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

NAME Laura Cox RT# RT. SEQ. ACCT # 03.23920 DATE 9-17-25 INT TN

MAILING ADDRESS CO. CITY

ADDRESS 5441 Lower Meigs Rd APT/LOT NO.

CITY Moultrie STATE GA ZIP CODE 31788

NEW CUSTOMER INFORMATION S.S. NO. DELV HOME PH RENT WORK PH 873-9809 CREDIT LITE PILOT PC EMPLOYER DR. USE LEASE

SERVICE REQUESTED: CASH CHARGE DATE PROMISED

email: lauracox0119@gmail.com cell # 229-873-9809

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: Tank set run line for Water Heater 873-9809

(229) 823-9809

Table with columns: TANK PICKUP/SET, TANK SIZE, SERIAL #, TANK %, TANK DESTINATION, DOT PERMANENTLY INSTALLED CONTAINERS (MANUFACTURED DATE, LAST TEST DATE, SIZE, SERIAL #, % FULL)

Table with columns: QTY, APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED, MODEL #, SERIAL NUMBER, UNIT PRICE, SALES AMOUNT

WORK PERFORMED: Set 120, Ran gas line for Rinnai - No leaks in system REGULATION INFORMATION MAKE: Rego MODEL: TR9 DATE CODE: 03C2025 VENT: Down APPLIANCES/EQUIP. SOLD CODE: WH MP MS CF PARTS/MAT. USED TANK RENT SALES TAX

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: LEAK AND PRESSURE TEST HIGH: 1st Stage 2nd Stage LOW START LOCK-UP: 11 PSI PSI START LOCK-UP: W.C. LABOR TANK OFF: PRESSURE 6 PSI PSI TANK OFF: PRESSURE W.C. TR AFTER 10 MINUTES: 6 PSI PSI AFTER 10 MINUTES: W.C. EQ PRESSURE AS LEFT: 11 PSI PSI PRESSURE AS LEFT: W.C. PIPING PRESSURE TEST START PSIG FINISH PSIG INV. TOTAL AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE. SERVICE REP. SIGNATURE DATE 9.22.2025 CUSTOMER SIGNATURE