

a left msg. JB

8/26/2025 11:31:03 AM

# WORK ORDER

## Steve Austin

36 Ridge Line Court  
Ellijay, GA 30536  
(470) 514-6950

Customer #: 204264  
Order #: 389355  
Location #: 280007  
Zone: B-042-TUE-  
Terms: Net 30

Tech: \_\_\_\_\_

**Map Code:**

**Service Code:** Propane Service

**Description:** 08/28/25 FINAL HOOK UP. YARD LINE IS THERE. ANODE TEST. CALL WILL 706-669-0426 - CCOF - CT

<b>Date Ordered:</b> 8/26/2025	<b>Scheduled Date:</b>	<b>Est. Completion:</b>	<b>Start:</b>	<b>Stop:</b>
--------------------------------	------------------------	-------------------------	---------------	--------------

<b>Name:</b>	<b>Last Service:</b> 8/14/2025	<b>Last Tune Up:</b>
<b>Contract:</b>	<b>SC Renewal:</b>	
<b>Manufact:</b>	<b>Model:</b>	
<b>Notes:</b>		
<b>Instructions:</b>		

**Service History:**

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



# PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 204264  
 Name: STEVE AUSTIN  
 Address: 36 RIDGE LINE COURT  
ELLIJAY, GA 30536

Date: 8/28/25  
 Instructions: FINAL HOOK YARD LINE THERE. ANODE  
TEST. CALL WILL 706-669-0425 GCOF  
 Order #: 389355

**Disclaimer:** This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

**Appliance Check:**

Appliance	FURNACE					
Manufacturer	RHEEM					
Model #	RCFY6821STANMC					
Serial #	W152501253					
Burner/Combustion Chamber	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Manual Shutoff	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Sediment Trap	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Pilot Safety System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Electronic Ignition System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Venting System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Combustion Air	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Taken Out of Service	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No				

**Container Check:**

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	m2432037	9006	triarc	2024	UG	9006

**Regulator(s):**

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			<input type="checkbox"/> Correct <input type="checkbox"/> Incorrect		
1st	MEC	1622H	<input checked="" type="checkbox"/> Correct <input type="checkbox"/> Incorrect		
2nd	Rego	3403B4	<input checked="" type="checkbox"/> Correct <input type="checkbox"/> Incorrect	11.1	12.7

**Piping System Leak Test:**

**Pressure Test:**

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	<input checked="" type="checkbox"/> Yes	_____ PSI	_____ PSI	_____ Mins	<input type="checkbox"/> Yes
_____ WC	_____ WC	_____ Mins	<input type="checkbox"/> No				<input type="checkbox"/> No

Comments:

**Customer Acknowledgment:** I acknowledge, by checking each of the following items, that:

- I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- I have smelled propane gas and can detect its odor.
- I have been told to consider installing one or more gas detectors.
- I have received safety information and told to read it and share it with all family members.
- I am satisfied with the service work performed.

Service Technician (Print)	ALEX CASH	Service Technician (Signature)		Date
Customer (Print)	CMAP	Customer (Signature)		Date



www.folgergas.com

# RINNAI WORK ORDER

Customer Acct #: 204264  
 Name STEVE AUSTIN  
 Address 36 RIDGELINE COURT  
ELLIJAY, GA 30536

Date: 8/14/25  
 Instructions: DROP 325UGW/50G@2.599G DROP ANODE BA  
CALL WILL WARTD 706-669-0426. CCOF  
 Order #: 387116

DESCRIPTION OF WORK	
COMMENTS:	
SERVICED BY:	

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

**FOR OFFICE USE ONLY**

Performed leak check  Yes  No  
 Gas check attached  Yes  No  
 Leak check Initial \_\_\_\_\_

Start Pressure \_\_\_\_\_ End Pressure \_\_\_\_\_ Time Held \_\_\_\_\_ System OK \_\_\_\_\_

% in Tank \_\_\_\_\_

AMOUNT REC'D
\$ _____
<input type="checkbox"/> CASH <input type="checkbox"/> CHECK # _____
<input type="checkbox"/> CREDIT CARD
# _____
EXP. DATE _____
<ul style="list-style-type: none"> <li>* I have received the Consumer Safety information &amp; material.</li> <li>* I am satisfied with the work performed.</li> <li>* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.</li> <li>* Signing agrees to _____ year contract for discount.</li> </ul>
_____ CUSTOMER SIGNATURE

Retail Price		Contract Price	
_____ Rinnai	\$ _____	\$ _____	
Standard Vent Kit	\$ _____	\$ _____	
Standard Install	\$ _____	\$ _____	
Total	\$ _____	\$ _____	
Tank Set		New Cust Special	
L P Gas /Gal	<b>2.999</b>	L P Gas /Gal	<b>2.599</b>
Gallons	<b>50</b>	Gallons	<b>50</b>
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	<b>149.95</b>	Fuel Total	<b>129.95</b>
Tank Lease/YR	<b>129.00</b>	1st yr Lease	<b>FREE</b>
Total Materials			<b>FREE<sup>F</sup></b>
Sub-Total			
Sales Tax			
Tank Set Fee	\$250	Tank Set Fee	<b>20.00</b>
Safety Inspection	\$129.95	\$29.95	<b>29.95</b>
Total Labor			
Total charges			
Prepay Bal On Account			
Safe Appliance Savings			<b>487.33</b>
<i>Safe Appliance Rebate</i>			<b>402.00</b>
<b>TOTAL BALANCE DUE</b>			