



congerlpgas.com

jas

117130

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME James Phillips RT# _____ RT. SEQ. _____ ACCT # 03-24100 DATE 9-29-25 INT JL

MAILING ADDRESS Sweetwater Rd CO. _____ CITY _____

ADDRESS 133 Will Rd APT/LOT NO. _____

CITY Moultrie STATE GA ZIP CODE 31768

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

NEW CUSTOMER INFORMATION	
S.S. NO. _____	DELV _____
HOME PH _____	RENT _____
WORK PH _____	CREDIT _____
LITE PILOT _____	PC _____
EMPLOYER _____	_____
DR. _____	USE _____ LEASE _____

email: _____

cell # _____

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

(229) 891-6067 Hang Water Heater to the left of power on wall

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
TS	120	1528495	10	gallons/AA					
10 x 4.099 = 40.99 + 4.80 + 18.95 =								64.74	

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
15	ft. 3/8" Copper				59.25
2	3/8" flare nut				3.90
1	REGO L4403772B467				79.95
1	3/8" flare ball valve				19.95
1	3/4" Sediment trap				40.00
1	Kingi REL60c 3IN. TA UA-095489				1,099.95
1	Isolation fit				75.00

WORK PERFORMED: <u>Set 120 gallon tank.</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE	1099.95
<u>Hung Kingi REL60c, AOS</u>	MAKE: <u>REGO</u>	MODEL: <u>L4403772</u>	PARTS/MAT. USED	MP	278.05
<u>Check OK, no leaks.</u>	DATE CODE: <u>050/25</u>	VENT: <u>down</u>	TANK RENT	MS	27.48
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE					TR 10.00
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:			SALES TAX	2.20	22.24
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐			1.52	88.00	.80
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐			LABOR		
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.			LD	180.00	
X			COMP	CF	18.95
CUSTOMER SIGNATURE			[GPC]	200.00	
HIGH: 1st Stage 2nd Stage LOW			INV. TOTAL		1593.93
START LOCK-UP: PSI	PSI	START LOCK-UP: 12 W.C.	AMOUNT RECEIVED	GPC	200.00
TANK OFF: PRESSURE PSI	PSI	TANK OFF: PRESSURE 9 W.C.			
AFTER 10 MINUTES: PSI	PSI	AFTER 10 MINUTES: 9 W.C.			
PRESSURE AS LEFT: PSI	PSI	PRESSURE AS LEFT: 12 W.C.			
PIPING PRESSURE TEST					
START PSIG	FINISH PSIG				

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY