



congerlpgas.com

116820

146 S. Ridge Ave.  
Tifton, GA 31794  
(229) 386-5574

306 S. Main St.  
Sylvester, GA 31791  
(229) 776-7336

604-B N. Broadfoot Blvd.  
Vidalia, GA 30474  
(912) 537-8722

3117 Veterans Parkway S.  
Moultrie, GA 31788  
(229) 985-6942

2310-B Highway 84 W  
Valdosta, GA 31602  
(229) 469-4250

NAME Classic Homes by Weaver RT# \_\_\_\_\_ RT. SEQ. \_\_\_\_\_ ACCT # 04-19957 DATE 10.2.25 INT APR

MAILING ADDRESS 237 Northside dr Valdosta GA 31601 CO. \_\_\_\_\_ CITY \_\_\_\_\_

ADDRESS 7 Pheasants Lane APT/LOT NO. \_\_\_\_\_

CITY Moultrie STATE Ga ZIP CODE 31788

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED \_\_\_\_\_

Set 120 for Rinnai

DIRECTIONS:

NEW CUSTOMER INFORMATION  
S.S. NO. \_\_\_\_\_ DELV \_\_\_\_\_  
HOME PH \_\_\_\_\_ RENT \_\_\_\_\_  
WORK PH \_\_\_\_\_ CREDIT \_\_\_\_\_  
LITE PILOT \_\_\_\_\_ PC \_\_\_\_\_  
EMPLOYER \_\_\_\_\_  
DR. \_\_\_\_\_ USE \_\_\_\_\_ LEASE \_\_\_\_\_

email: weaverhomes@yahoo.com  
cell # 929-563-5365

PAY BILL ONLINE @congerlpgas.com

| TANK PICKUP/SET | TANK SIZE | SERIAL # | TANK % | TANK DESTINATION | DOT PERMANENTLY INSTALLED CONTAINERS |                |      |          |        |
|-----------------|-----------|----------|--------|------------------|--------------------------------------|----------------|------|----------|--------|
| TS              | 120       | 1528496  | 100gal | AG on Site       | MANUFACTURED DATE                    | LAST TEST DATE | SIZE | SERIAL # | % FULL |
|                 |           |          |        |                  |                                      |                |      |          |        |
|                 |           |          |        |                  |                                      |                |      |          |        |

| QTY | APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED | MODEL # | SERIAL NUMBER | UNIT PRICE | SALES AMOUNT |
|-----|----------------------------------------------|---------|---------------|------------|--------------|
| 1   | Rinnai Tankless Water Heater                 | RE180e  | TD.UA-058721  |            | 899 95       |
| 15  | 3/8 Copper                                   |         |               |            | 33 60        |
| 2   | 3/8 Flare Nuts                               |         |               |            | 2 16         |
| 1   | Sediment Trap                                |         |               |            | 21 83        |
| 1   | B46R Regulator                               |         |               |            | 58 11        |
| 1   | Cutoff Valve                                 |         |               |            | 13 11        |
| 1   | MIP                                          |         |               |            | 1 99         |
|     |                                              |         |               |            |              |
|     |                                              |         |               |            |              |

|                                           |                          |                   |                         |            |               |
|-------------------------------------------|--------------------------|-------------------|-------------------------|------------|---------------|
| WORK PERFORMED: <u>Set 120 for Rinnai</u> | REGULATION INFORMATION   |                   | APPLIANCES/ EQUIP. SOLD | CODE       |               |
| <u>No leaks in system</u>                 | MAKE: <u>Rego</u>        | MODEL: <u>TR9</u> | PARTS/MAT. USED         | <u>MIP</u> | <u>130 80</u> |
|                                           | DATE CODE <u>0502024</u> | VENT: <u>Down</u> | TANK RENT               | <u>MS</u>  | <u>16 85</u>  |

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

- 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐
- 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X \_\_\_\_\_  
CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST

| HIGH:              | 1st Stage | 2nd Stage | LOW                |
|--------------------|-----------|-----------|--------------------|
| START LOCK-UP:     | 10 PSI    | PSI       | START LOCK-UP:     |
| TANK OFF: PRESSURE | 6 PSI     | PSI       | TANK OFF: PRESSURE |
| AFTER 10 MINUTES:  | 6 PSI     | PSI       | AFTER 10 MINUTES:  |
| PRESSURE AS LEFT:  | 10 PSI    | PSI       | PRESSURE AS LEFT:  |

SALES TAX \_\_\_\_\_ %  
1.35 72.00  
152 10.46

LABOR LB 150 00

GC 200.00

GC (200.00)

PIPING PRESSURE TEST

INV. TOTAL 1301.88

START \_\_\_\_\_ PSIG FINISH \_\_\_\_\_ PSIG AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY