



congerlpgas.com

116822

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Classic Homes by Weaver RT# _____ RT. SEQ. _____ ACCT # 04-19957 DATE 10.2.25 INT APR

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 96 Baell Trace Court APT/LOT NO. _____

CITY Moultrie STATE Ga ZIP CODE _____

NEW CUSTOMER INFORMATION
S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

email: _____

cell # _____

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: _____

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
TS	120	1528493	10gal	AG on Site	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rinnai Tankless Water Heater	RE180L	TD-UA-058727		899 95
15	3/8 Copper				33 60
2	3/8 Flare Nuts				2 16
1	Sediment Trap				21 83
1	B46R Regulator				58 11
1	Cutoff Valve				13 11
1	MIP				1 99

WORK PERFORMED: <u>Set 120 for Rinnai</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE	
<u>No leaks in system</u>	MAKE: <u>Rego</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED	<u>MP</u>	<u>130 80</u>
	DATE CODE: <u>0502025</u>	VENT: <u>Down</u>	TANK RENT	<u>MS</u>	<u>16 85</u>
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE					<u>CF</u> <u>18 95</u>
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:			SALES TAX	<u>1.35</u>	<u>72.00</u>
LEAK AND PRESSURE TEST			____ %	<u>1.52</u>	<u>10.46</u>
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH: 1st Stage	2nd Stage	LOW		
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	START LOCK-UP: <u>10</u> PSI	PSI	START LOCK-UP: _____ W.C.	LABOR	<u>LB</u> <u>150 00</u>
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: PRESSURE <u>6</u> PSI	PSI	TANK OFF: PRESSURE _____ W.C.		<u>GR</u> <u>200.00</u>
	AFTER 10 MINUTES: <u>6</u> PSI	PSI	AFTER 10 MINUTES: _____ W.C.		<u>GR</u> <u>(200.00)</u>
	PRESSURE AS LEFT: <u>10</u> PSI	PSI	PRESSURE AS LEFT: _____ W.C.		
X	PIPING PRESSURE TEST		INV. TOTAL		<u>1301.88</u>
CUSTOMER SIGNATURE	START	PSIG	FINISH	PSIG	AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

10.2.2025
DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY