



congerlpgas.com

INVOICE / WORK ORDER NO.

115246

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Troy Spires RT# _____ RT. SEQ. _____ ACCT # 7-18450 DATE 10-1-25 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 85 Hilltop Dr. APT/LOT NO. _____

CITY Lumber City STATE GA ZIP CODE 31549

SERVICE REQUESTED: ☒ CASH ☐ CHARGE DATE PROMISED _____

Install w/H & tie tanks together
run line

DIRECTIONS:

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email:

cell # 912 253-0206

PAY BILL ONLINE @congerlpgas.com

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Regulator w/H	RK199IN	TD.BA-080532	1799.95	1799.95
1	3/4 poly tee			159.95	159.95
1	3/4 flex riser			84.95	84.95
75	3/4 poly			.99	74.25
1	3/4 Maxitrol			79.95	79.95
1	TR96 regulator			84.95	84.95
1	1/4" R Regulator			84.95	84.95
2	CUTOFFS			29.95	39.90
1	Sediment trap			75.00	75.00

WORK PERFORMED:	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE
	MAKE: <u>Rego</u>	MODEL: <u>TR96</u>	PARTS/MAT. USED	
	DATE CODE: <u>19D2022</u>	VENT: <u>Dura</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐		HIGH: 1st Stage 2nd Stage	LOW	%
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐		START LOCK-UP: 10 PSI PSI	START LOCK-UP: W.C.	LABOR
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE 6 PSI PSI	TANK OFF: PRESSURE W.C.	MS
		AFTER 10 MINUTES: 6 PSI PSI	AFTER 10 MINUTES: W.C.	TECHNICIAN
		PRESSURE AS LEFT: 10 PSI PSI	PRESSURE AS LEFT: W.C.	GR
		PIPING PRESSURE TEST		INV. TOTAL
X <u>Troy Spires</u> CUSTOMER SIGNATURE		START PSIG	FINISH PSIG	AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY