

← Confirmed &

9/4/2025 11:39:35 AM

WORK ORDER

Art Miller

205 Notia Vista II
Blairsville, GA 30512
(706) 435-8298

Customer #: 203435
Order #: 395285
Location #: 278969
Zone: B-003-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 09/10/25 - T/I 30" SUPER SASS W/VFSR AND ON/OFF
REMOTE - T/I MONITOR - FINAL HOOK, HOOK UP ALL
APPLIANCE, HVAC, W/H, STOVE AND DRYER - STOVE AND
DRYER ALREADY CONVERTED. WANTS A T FOR FUTURE
GRILL AND BLACKSTONE AND ONE QUICK DISCONNECT.
ANODE TEST - CALL 706-435-8298 - EMAIL INVOICE - CT

Date Ordered: 9/4/2025	Scheduled Date:	Est. Completion:	Start:	Stop:
------------------------	-----------------	------------------	--------	-------

Name:

Last Service: 7/7/2025

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 203535

Date: 9/10/25

Name: ART MILLER

Instructions: T/I 30" SUP SASS W/ON/OFF REMOTE. T/I
MONITOR. FINAL HOOK, HOOK UP ALL APPLIANCES. T
FOR FUTURE GRILL AND BLACKSTONE. 1 QUICK DISCON

Address: 205 NOTLA VISTA II

Order #: 395285

BLAIRSVILLE, GA 30512

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Water Heater	Stove	Furnace	Dryer	Log Set	
Manufacturer	Rinnai	Kitchen Aid	Rheem	Moytag	Empire	
Model #	REU-NBP3237FF	HFGCS06J0N7	RCF24821	Data Plate	6FSR-30-4	
Serial #	5G-BA-105734	DE1002017	W3929	NV	2514P409638	
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☒ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	M2432557	Good	Torrac	2024	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rcso	39037R9	10 24	☒ Correct ☐ Incorrect	
2nd	MEL	1622E	20 Nov 23	☒ Correct ☐ Incorrect	11.1

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
120 PSI	120 PSI	10 Mins	☒ Yes	_____ PSI	_____ PSI	_____ Mins	☐ Yes
_____ WC	_____ WC	_____ Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Alex Cash	Service Technician (Signature)	Date
Customer (Print)	Art Miller	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 203435

Date: 07/07/2025

Name ART MILLER

Instructions: DROP 500UG W/50G@2.599 + DROP ANOI

Address 205 NOTLA VISTA II

ROUGH IN YARD LINE. CALL: 706-435- 8298 ACH-JB

BLAIRSVILLE, GA 30512

Order #: 372848

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$

\$

Standard Vent Kit \$

\$

Standard Install \$

\$

Total \$

\$

Tank Set

New Cust Special

L.P. Gas /Gal 2.999

L.P. Gas /Gal 2.599

Gallons 50

Gallons 50

FRCC \$9.79

FRCC \$9.79

9.79

Fuel Total 149.95

Fuel Total 129.95

129.95

Tank Lease/YR 129.00

1st yr Lease FREE

FREE

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Tank Set Fee

20.00

Safety Inspection \$129.95

\$29.95

29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings

487.33

Safe Appliance Rebate 600.00

TOTAL BALANCE DUE