

confirmed JB

9/12/2025 1:27:18 PM

WORK ORDER**Lawrence Parker**

490 Turkey Ridge Road
Morganton, GA 30560
(239) 229-2652

Customer #: 204452
Order #: 396676
Location #: 280229
Zone: B-008-WED-
Terms: Net 30

Tech: _____

Map Code:**Service Code:** Propane Service

Description: 09/18/25 - T/I 250AG W/200G@2.599G. RUN YARD LINE.
HOOK UP STOVE, DRYER (BOTH ALREADY CONVERTED)
W/HEATER, AND TAKE A GAS STARTER IN CASE ONE IS
NEEDED. CALL 239-229-2652 - \$ ON SITE - CT

Date Ordered: 9/12/2025	Scheduled Date:	Est. Completion:	Start:	Stop:
--------------------------------	------------------------	-------------------------	---------------	--------------

Name:**Contract:****Manufact:****Notes:****Instructions:****Last Service:****SC Renewal:****Model:****Last Tune Up:****Service History:**

Date	Invoice #	Tech	Problem Reported	Service Notes
-------------	------------------	-------------	-------------------------	----------------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 204452

Date: 9-18-25

Name: LAWRENCE PARKER

Instructions: T/I 250 W/200G @ 2.599 RUN YARD LINE
HOOK UP STOVE DRYER 9CONVERTED0 W/H , TAKE GAS
STARTER IN CASE. 239-229-2652 \$ ON SITE

Address: 490 TURKEY RIDGE RD

Order #: 396676

MORGANTON GA 30560

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove	Dryer	Waterheater	Log lighter		
Manufacturer	Thor	Whirlpool	Rheem	NV		
Model #	LR636DIUPT	WGD95HEDMO	RT6H5R11	NV		
Serial #	2591221	M42701289	W352443150	NV		
Burner/Combustion Chamber	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M1350500	Good	Trinity	2013	AG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	LV4403TR9	NV	☒ Correct ☐ Incorrect	
2nd	MEC	1622E	30 MAR 24	☒ Correct ☐ Incorrect	11.9
					12.8

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
90 PSI	90 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☐ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print) BRIAN BRADLEY	Service Technician (Signature) 	Date 9-18-25
Customer (Print) CNAPS	Customer (Signature) 	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 204452
Name LAWRENCE PARKER
Address 490 TURKEY RIDGE RD
MORGANTON GA 30560

Date: 9-18-25
Instructions: T/I 250 W/200G @ 2.599 RUN YARD LINE
HOOK UP STOVE DRYER(CONVERTED) W/H TAKE GAS
STARTER JUST IN CASE 239-229-2652 \$ ON SITE CT
Order #: 396676

DESCRIPTION OF WORK
COMMENTS:
SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY	
Performed leak check	Yes No
Gas check attached	Yes No
Leak check	Initial
Start Pressure	End Pressure Time Held System OK

% in Tank

AMOUNT REC'D
\$
☐ CASH ☐ CHECK #
☐ CREDIT CARD
#
EXP. DATE
* I have received the Consumer Safety information & material. * I am satisfied with the work performed. * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment. * Signing agrees to year contract for discount.
CUSTOMER SIGNATURE

Retail Price		Contract Price
Rinnai	\$	\$
Standard Vent Kit	\$	
Standard Install	\$	
Total	\$	\$
Tank Set		New Cust Special
L.P. Gas /Gal	2.999	L.P. Gas /Gal 2.599
Gallons	200	Gallons 200
FRCC	\$9.79	FRCC \$9.79
Fuel Total	599.80	Fuel Total 519.80
Tank Lease/YR	99.00	1st yr Lease FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee	\$250	Tank Set Fee 20.00
Safety Inspection	\$129.95	\$29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		553.63
Safe Appliance Rebate		300.00
TOTAL BALANCE DUE		