



congerlpgas.com

INVOICE / WORK ORDER NO.

120900

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574306 S. Main St.
Sylvester, GA 31791
(229) 776-7336604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-87223117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-69422310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250NAME Bruce Greene RT# _____ RT. SEQ. _____ ACCT # 02-16545 DATE 9-23-25 INT Ja

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 1498 Shingler Sumner Rd APT/LOT NO. _____CITY Sumner STATE GA ZIP CODE _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____email: bxlgreene@bellsouth.netcell # 912-210-2190

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

DIRECTIONS:

Set tank, hook up water heater, stove, dryer

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
<u>TS</u>	<u>250</u>	<u>2539</u>	<u>10 gallons @ 38.49</u>	<u>loan</u>				<u>38.49 (01)</u>	

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>Rinnai tankless RE180</u>	<u>RE180</u>	<u>THWA-118041</u>	<u>(AP)</u>	<u>1199.95</u>
	<u>Sediment trap with cutoff valve</u>				<u>44.95</u>
	<u>B46R regulator</u>				<u>79.95</u>
<u>2</u>	<u>1/2" cutoff valves</u>			<u>19.95</u>	<u>39.90</u>
<u>2</u>	<u>1/2x48 flex lines</u>			<u>34.95</u>	<u>69.90</u>
	<u>Dryer duct</u>				<u>51.95</u>
	<u>Stove glow bar</u>				<u>99.95</u>
	<u>1/2" swivel</u>				<u>4.95</u>
<u>2</u>	<u>1/2" flare nuts</u>			<u>2.95</u>	<u>5.90</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/ EQUIP. SOLD	CODE	SALES AMOUNT
<u>Set tank, hooked up, w/h, stove, dryer</u>	MAKE: <u>Rega</u> MODEL: <u>TR9</u>	<u>(MP)</u>	<u>(MS)</u>	<u>590.95</u>
	DATE CODE: <u>0902024</u> VENT: <u>Down</u>	<u>(GR)</u>	<u>(200.00)</u>	
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				<u>CF</u> <u>18.95</u>

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:			LEAK AND PRESSURE TEST			SALES TAX				9600 15.5 4728 3.0 716		
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐			HIGH:		1st Stage	2nd Stage	LOW		_____%			
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐ I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.			START LOCK-UP:		9.2	PSI	PSI	START LOCK-UP:		13.1	W.C. LABOR	
			TANK OFF: PRESSURE		6.0	PSI	PSI	TANK OFF: PRESSURE		90	W.C.	
			AFTER 10 MINUTES:		6.0	PSI	PSI	AFTER 10 MINUTES:		90	W.C.	
			PRESSURE AS LEFT:		90	PSI	PSI	PRESSURE AS LEFT:		11.0	W.C.	
X _____ CUSTOMER SIGNATURE			PIPING PRESSURE TEST						INV. TOTAL		2792.84	
			START		6.0	PSIG	FINISH	6.0	PSIG	AMOUNT RECEIVED		

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY