



congerlpgas.com

INVOICE / WORK ORDER NO.

121012

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Pine Forest Church #2 RT# _____ RT. SEQ. _____ ACCT # 03-2213 DATE 10-3-25 INT 108

MAILING ADDRESS PO Box 83 CO. _____ CITY _____

ADDRESS 601 Pine Forest Rd APT/LOT NO. _____

CITY Sylvester STATE GA ZIP CODE 31791

SERVICE REQUESTED: ☐ CASH ☐ CHARGE • DATE PROMISED _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: _____

cell # _____

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

Installed tankless w/h

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>Rinnai</u>	<u>REP160e</u>	<u>PLUA-119926</u>	<u>(WH)</u>	<u>999.95</u>
<u>19</u>	<u>3/8" copper</u>			<u>3.95</u>	<u>75.05</u>
<u>15</u>	<u>1/2" copper</u>			<u>4.95</u>	<u>74.25</u>
	<u>Sediment trap with cutoff valve</u>				<u>49.95</u>
	<u>BlueR regulator</u>				<u>79.95</u>
<u>2</u>	<u>3/8 flare nuts</u>			<u>1.95</u>	<u>3.90</u>
<u>2</u>	<u>1/2" flare nuts</u>			<u>2.95</u>	<u>5.90</u>
	<u>1/2 union</u>			<u>2.95</u>	<u>3.95</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>Installed Rinnai</u>	MAKE: <u>Rego</u> MODEL: <u>TR9</u>	<u>(MFA)</u>	<u>292.95</u>
<u>tankless w/h</u>	DATE CODE: <u>10C2024</u> VENT: <u>Down</u>	PARTS/MAT. USED	<u>(MS)</u> <u>39.18</u>
		TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST				SALES TAX			80.00
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58	☐	HIGH:	1st Stage	2nd Stage	LOW	_____ %			23.44
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54	☐	START LOCK-UP:	9.2 PSI	PSI	START LOCK-UP:	13.1 W.C.	LABOR		360.00
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE	6.0 PSI	PSI	TANK OFF: PRESSURE	9.0 W.C.	(GPR)	(200.00)	
		AFTER 10 MINUTES:	6.0 PSI	PSI	AFTER 10 MINUTES:	9.0 W.C.			
		PRESSURE AS LEFT:	9.0 PSI	PSI	PRESSURE AS LEFT:	16.0 W.C.			
X _____		PIPING PRESSURE TEST				INV. TOTAL			1619.12
CUSTOMER SIGNATURE		START	6.0 PSIG	FINISH	6.0 PSIG	AMOUNT RECEIVED			

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY