



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

congerlpgas.com

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

121364

NAME Chad McDonald
McDonald CONST

MAILING ADDRESS 3805 GA 313 N CO. _____ CITY _____

ADDRESS 313 N - 3805 APT/LOT NO. _____

CITY _____ STATE _____ ZIP CODE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

Install WH RE199

DIRECTIONS:

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email:

cell # 881-9477

PAY BILL ONLINE @congerlpgas.com

DOT PERMANENTLY INSTALLED CONTAINERS

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
TS	250	140456B							
		LOAN							

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rinnai	RE199x	TDUA-054293	(AP)	1399.95
1	TR9 regulator				84.95
1	pigtail				9.95
2	1/2" flex riser			59.95	119.90
	1/2" rigid riser				74.95
	1/2" poly tee			65	89.95
27'	1/2" poly pipe				17.55
	Blue regulator				79.95
	Blue regulator				79.95

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
up water heater + generator	MAKE: Rego MODEL: TR9	PARTS/MAT. USED	(MP) 1395.95
	DATE CODE: 10C2024 VENT: Down	TANK RENT	(MS) 116.16

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

- 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐
- 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST			
HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP:	9.2 PSI	PSI	START LOCK-UP: 12.9 W.C.
TANK OFF: PRESSURE	6.0 PSI	PSI	TANK OFF: PRESSURE 9.0 W.C.
AFTER 10 MINUTES: PRESSURE	6.0 PSI	PSI	AFTER 10 MINUTES: 9.6 W.C.
AS LEFT: PRESSURE	9.0 PSI	PSI	AS LEFT: 11.0 W.C.

PIPING PRESSURE TEST

START	6.0 PSIG	FINISH	6.0 PSIG
-------	----------	--------	----------

SALES TAX	18.95
	112.95
	11.63
	929
LABOR	540.00
	(GR) (260.00)
INV. TOTAL	3505.50
AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY