



HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

INVOICE

No 11155

NAME	<u>Oak Dale Motel</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>2320 Hatch Parkway S.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	TE PROMISED	
PHONE	<u>912-367-2659</u>	DATE COMPLETED	<u>1-2-25</u>
LOCATION		TERMS	

INSTRUCTIONS pick up 120 gallon tank, set 250 gallon tank, install tankless water heater, run gas line to far end where other tank was at

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE199e tankless water heater w/ isolation valves, serial # RC.UA-044570		1500 00
119	gallon of propane	2 59	308 21
2	Rego LV340384 second stage regulator	59 95	119 90
185'	1/2" coated copper tubing	3 29	608 65
1	1/2" cut off valve		12 95
14	1/2" flare nut	1 60	22 40
3	1/2" x 1/2" male adaptor	3 09	9 27
all	other gas fittings, pex adaptor, thread sealant		43 29
1	mini excavator rental		150 00

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:	SERVICES PERFORMED <u>picked up 120 gallon tank, set 250 gallon tank, installed tankless water heater, ran gas lines, used excavator to dig trench, ran gas line to far end & hooked up to other water heater & digger, ran pressure check</u>	TOTAL MATERIAL	2774 67
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐			
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐			
	TOTAL TIME _____ HOURS	LABOR	6 50 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED	SUBTOTAL	
X	BY <u>Daniel M. Reynolds, Nolan</u>	SALES TAX	221 97
CUSTOMER'S SIGNATURE		TOTAL DUE	3646 64

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				- GPGA rebate \$200.00 AMOUNT	
INSTALLATION ☒ OR TURN ON		REMOVAL ☐ OR TURN OFF		LEAK AND PRESSURE TEST	
				HIGH	LOW
SIZE: <u>250</u>		SIZE: <u>120</u>		START LOCK UP:	START JACK UP:
S/N: <u>1526908</u>		S/N: <u>1527257</u>		TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>200 gal</u>		GALLONS OR READING: <u>81 gal</u>		AFTER 10 MINUTES:	AFTER 10 MINUTES:
				PRESSURE AS LEFT:	PRESSURE AS LEFT:
				RECEIVED BY _____	
				DATE _____	
				SERVICES RECEIVED BY _____	

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 1/2/25
 Name Oak Dale Motel Company Sikes Propane, Inc.
 Address 2320 Hatch Parkway S. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) _____ (Home) 912-367-2659

Appliance Check

Appliance	gas dryer	water heater	water heater		
Manufacturer	Speed Queen	Rinnai	Rinnai		
Model #	ADG48RGS 117TW01	RE199e	RL94e		
Serial #	22020295 23	RC-UA-044 570	LE-UA-033 966		
BTU's	22,500	199,000	199,000		
Burner / Com. Chamber	ok	ok	ok		
Man. Shutoff / Sed. Trap	installed	installed	existing		
Control / Pilot Safety System	ok	ok	ok		
Venting System	ok	ok	ok		
Combustion Air	2 months	new	5yrs		
Taken Out Of Service Or Operation					

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
250	1526908	Quality Steel	2024	ok	new	09D22	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	
110psi.	110psi.	10min.	Work Order	☒ ☒ ☒

Piping Check

Materials	Size	Cover / Protection
coated copper	1/2", 5/8", 3/4"	ok

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	
9in. wc.	9in. wc.	10min.	Work Order	☒ ☒ ☒

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection		
first	Rego	06D2024 / LV4403TR9	n-c		
second	Rego	07E2024 / LV3403B4	down		
second	Rego	07E2024 / LV3403B4	down		

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.