

- SALES
- SERVICE
- INSTALLATION

MODERN GAS
THE PROS IN PROPANE SINCE 1954

ENERGY FOR EVERYONE
propane

RH/CL

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 877070	Date Written 11/6/25	Taken By MEH	Date Completed 11/13/25
Branch - Customer No. 1-12749	Home 229 435-5425	Work 11:00	Time Completed 12:00
Name SINGLETARY CONSTR #14	Cell LOT 97 THE GROVES 12/2024	LAST HERE JOSH 7 HEATHER OLIVER 1282 BILLY MARTIN ROAD 1/2024	
Address POBX 70815	City ALBANY, GA	State 31708	Zip
Service Address 205 Thistledown Dr. LEESBURG, GA 31763-1864			

Work to be performed:	Work completed
DELIVER AND INSTALL RINNAI RL75iP, WITH ROOF DISCHARGE TERMINAL, 189951 FLASHING. OTHER VENTING. TAKE CAMCO DRAIN PAN ALSO IN BY TERRY 343-5425 CELL:	Delivered installed and vented Rinnai

Qty	Materials	Price	Amount	Qty	Materials	Price	Amount
1	W-R 11420	39.00	39.00	1	W-R RL7510	90.00	90.00
	CAMCO Drain Pan				Internal Drain		
	RL 75i			1	W-R 184118	72.00	72.00
	NECA-057054				Roof Discharge		
				1	W-R 184958	72.00	72.00
					Flashing		
				1	224053 39" Vent	59.-	59.-
				2	224052 19.5 vent	52.-	104.-
				2	224063 90° VENT EL	43.-	86.-

Less Check		Flow Check		Lock-up Check		SHOP OR TRUCK SUPPLIES		14 50	
Manometer Reading at Start 0.6	Manometer Reading After 10 minutes 0.6	Manometer Reading Under Load	Manometer Reading			MATERIAL TOTAL		1353 50	
Central Heating	Water Heater	Range	Clothes Dryer			TRIP CHARGE			
Manufacturer	Rinnai					LABOR			
Model No.	RL75iP					SUB-LABOR Rebate		<200 00>	
Serial No.	NECA-057054					PERMIT			
Sed. Trap	I I					SHIPPING/FREIGHT			
Fuel/BTU	000	180 000	N/A	N/A		000			
AGE	New					Thank You		SALES TAX	
Shut off Installed	yes					TOTAL		108 23	

<input type="checkbox"/> CASH	RECEIVED BY	Date 11/13/25	ANY UNUSED GAS PIPING OUTLETS INDOORS?	<input type="checkbox"/> YES <input type="checkbox"/> NO
<input type="checkbox"/> CHECK			"IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT I-THREADED PLUG OR CAP?"	<input type="checkbox"/> YES <input type="checkbox"/> NO
Work Completed by Curtis Royce	Customer Signature	Date 11/13/25	CUSTOMER AVAILABLE	<input type="checkbox"/> YES <input type="checkbox"/> NO
I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY			CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE	<input type="checkbox"/> YES <input type="checkbox"/> NO