



congerlpgas.com

111229

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574306 S. Main St.
Sylvester, GA 31791
(229) 776-7336604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-87223117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2-13-25

NAME North Edwards RT# _____ RT. SEQ. _____ ACCT # 13-22724 DATE 12-17-24 INT 10

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 20 Dog Wood dr APT/LOT NO. _____CITY Mac Hore STATE GA ZIP CODE 31768

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____

HOME PH _____ RENT _____

WORK PH _____ CREDIT _____

LITE PILOT _____ PC _____

EMPLOYER _____

DR. _____ USE _____ LEASE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

email: _____

cell # 229-823-1043

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

Replace old conv Tank
WH

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
	<u>500</u>	<u>cot</u>			MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>RX 180 IN</u>		<u>SE.BA-081523</u>		<u>1699.95</u>
<u>1</u>	<u>misc Iron</u>				<u>60.00</u>
<u>1</u>	<u>Vent</u>				<u>35.00</u>

WORK PERFORMED: <u>Install TWH</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	<u>WPA</u>	<u>1699.95</u>	
<u>gas ck no leaks</u>	MAKE: <u>Rego</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED	<u>mp</u>	<u>95.00</u>	
	DATE CODE: <u>1-99</u>	VENT: <u>Hor</u>	TANK RENT	<u>MS</u>	<u>16.50</u>	
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE					<u>CF</u>	<u>14.95</u>
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:			SALES TAX	<u>1.32</u>	<u>136.00</u>	
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	LEAK AND PRESSURE TEST		%	<u>120</u>	<u>7.60</u>	
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	HIGH: 1st Stage	2nd Stage	LOW	LABOR	<u>LAB</u>	<u>180.00</u>
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	START LOCK-UP: PSI	PSI	START LOCK-UP: <u>13.6</u> W.C.	<u>GPC</u>	<u>400.00</u>	
	TANK OFF: PRESSURE PSI	PSI	TANK OFF: PRESSURE <u>9</u> W.C.			
	AFTER 10 MINUTES: PSI	PSI	AFTER 10 MINUTES: <u>9</u> W.C.			
	PRESSURE AS LEFT: PSI	PSI	PRESSURE AS LEFT: <u>13.6</u> W.C.			
X	PIPING PRESSURE TEST		INV. TOTAL	<u>GPC</u>	<u>400.00</u>	
CUSTOMER SIGNATURE _____			AMOUNT RECEIVED	<u>2152.52</u>		
	START PSIG	FINISH PSIG				

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER-COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY; BLUE/OFFICE COPY