



congerlpgas.com

INVOICE / WORK ORDER NO.

2-14-25 117407

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Farmers Gin And Planter RT. SEQ. _____ ACCT # 03-21676 DATE 2-10-25 INT 0
Larone Strickland

MAILING ADDRESS 2595 Hwy 133 South CO. _____ CITY _____

ADDRESS _____ APT/LOT NO. _____

CITY _____ STATE _____ ZIP CODE _____

NEW CUSTOMER INFORMATION
S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: _____

cell # _____

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

3822 Hwy 133 South. Moultrie

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
		<u>1-147563</u>			MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Re 75ep		<u>PC-CA-042947</u>		<u>999.95</u>
1	Misc Iron				<u>60.00</u>
1	shut off				<u>14.95</u>
2	Flare nuts				<u>4.18</u>
20	copper				<u>99.00</u>

WORK PERFORMED: <u>Hang TWH</u>	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE
<u>Gasck no leaks</u>	MAKE: <u>Rego</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED	
	DATE CODE: <u>1-24</u>	VENT: <u>Hor</u>	TANK RENT	
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				<u>14.95</u>

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX _____ %
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH:	1st Stage	2nd Stage	LOW
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	START LOCK-UP:	PSI	PSI	START LOCK-UP: <u>13.5</u> W.C.
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: PRESSURE	PSI	PSI	TANK OFF: PRESSURE <u>9</u> W.C.
	AFTER 10 MINUTES: PRESSURE	PSI	PSI	AFTER 10 MINUTES: <u>9</u> W.C.
	PRESSURE AS LEFT:	PSI	PSI	PRESSURE AS LEFT: <u>13.5</u> W.C.
X _____	PIPING PRESSURE TEST		INV. TOTAL	
CUSTOMER SIGNATURE	START	PSIG	FINISH	PSIG
			AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

[Signature]

X