



congerlpgas.com

INVOICE / WORK ORDER NO.

117412

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Angela Castellon RT# _____ RT. SEQ. _____ ACCT # 03-21513 DATE 2-17-25 INT _____

MAILING ADDRESS 114 Dogwood Circle CO. _____ CITY _____

ADDRESS _____ APT/LOT NO. _____

CITY _____ STATE _____ ZIP CODE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: aaacastellon@gmail.com

cell # 229 891-0121

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

Remod

Dropped of poly pipe

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
	120	605460			MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	RE 180		5KUA-145313		1099.95
1	Shut off				19.95
120	Poly				78.00
2	Copper certs				99.90
10	Copper				49.50
2	Flare nuts				4.18
1	Misc Iron				60.00
1	Reg				79.95

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
Install TWH	MAKE: <u>Rego</u> MODEL: <u>T189</u>	PARTS/MAT. USED	
gas ck No leaks	DATE CODE: <u>4-22</u> VENT: <u>Hor</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:	LEAK AND PRESSURE TEST	SALES TAX
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH: 1st Stage 2nd Stage LOW	_____ %
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐	START LOCK-UP: PSI PSI START LOCK-UP: <u>13.5</u> W.C.	LABOR
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: PRESSURE PSI PSI TANK OFF: PRESSURE <u>9</u> W.C.	GPC
	AFTER 10 MINUTES: PSI PSI AFTER 10 MINUTES: <u>9</u> W.C.	
	PRESSURE AS LEFT: PSI PSI PRESSURE AS LEFT: <u>13.5</u> W.C.	
X	PIPING PRESSURE TEST	INV. TOTAL
CUSTOMER SIGNATURE	START PSIG FINISH PSIG	AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

2-14-25

X