



congerlpgas.com

INVOICE / WORK ORDER NO.

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

111256

Registered 12-27-25

NAME Charlottie Kilgore RT# _____ ACCT # 03-12535 DATE 12-16-24 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 270 Lewis Rd APT/LOT NO. _____CITY Moultrie STATE GA ZIP CODE 31788

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____

HOME PH _____ RENT _____

WORK PH _____ CREDIT _____

LITE PILOT _____ PC _____

EMPLOYER _____

DR. _____ USE _____ LEASE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

email: _____

cell # _____

PAY BILL ONLINE @ congerlpgas.com

Wants Water Heater
Fix

DIRECTIONS:

(229) 985-2702

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	RL 75ep		RD-CA-069939		999.95
1	Misc Iron				600.00
1	Shutoff				19.95

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>Install tank</u>	MAKE: <u>Rego</u> MODEL: <u>Y9</u>	PARTS/MAT. USED	
<u>gas ck no leaks.</u>	DATE CODE: <u>2-23</u> VENT: <u>40</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:	LEAK AND PRESSURE TEST	SALES TAX
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH: 1st Stage 2nd Stage LOW	_____ %
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	START LOCK-UP: PSI PSI START LOCK-UP: <u>13.7</u> W.C.	LABOR <u>100.00</u>
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: PRESSURE PSI PSI TANK OFF: PRESSURE <u>9</u> W.C.	<u>GFC</u> <u>400.00</u>
	AFTER 10 MINUTES: PSI PSI AFTER 10 MINUTES: <u>9</u> W.C.	
	PRESSURE AS LEFT: PSI PSI PRESSURE AS LEFT: <u>13.7</u> W.C.	
X _____	PIPING PRESSURE TEST	INV. TOTAL
CUSTOMER SIGNATURE	START PSIG FINISH PSIG	AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

[Signature]

12-27-24

x