



congerlpgas.com

INVOICE / WORK ORDER NO.

110424

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME Chill Farms ^{Sam Watson Barniks} RT# _____ RT. SEQ. _____ ACCT # 03-22322 ¹⁷⁸⁰² DATE 1-20-25 INT 10

MAILING ADDRESS _____ CO. _____ CITY _____ S.S. NO. _____ DELV _____

ADDRESS 356 Frostin Doonan rd APT/LOT NO. _____ HOME PH _____ RENT _____

CITY Moultrie STATE GA ZIP CODE 31788 WORK PH _____ CREDIT _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____ LITE PILOT _____ PC _____

Second House Water Heater email: Sam Watson @chillfarms cell # 229-941-5859

DIRECTIONS: upright 120 Replaced 2 Elec WH

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
<u>TS</u>	<u>120</u>	<u>2594796</u>			MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	RE7Sep	P.L.	CA-042068		999.95
1	RE7Sep	P.L.	CA-03944		999.95
2	B46R		033046 039944		159.90
1	Black Iron				200.00
2	shut offs				39.90
1	3/4 Shark Bite Fittings for water				60.00
1	Elec wire				40.00
30	gal gas				

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>TS Run line</u>	MAKE: <u>Rego</u> MODEL: <u>TR9</u>	PARTS/MAT. USED	
<u>Install 2 TWH gas</u>	DATE CODE: <u>4-24</u> VENT: <u>Hor</u>	TANK RENT	
<u>CK no leaks</u>			

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:	LEAK AND PRESSURE TEST	SALES TAX
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH: 1st Stage 2nd Stage LOW	_____%
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	START LOCK-UP: PSI PSI START LOCK-UP: <u>13.6</u> W.C.	LABOR
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: PRESSURE PSI PSI TANK OFF: PRESSURE <u>9</u> W.C.	
	AFTER 10 MINUTES: PSI PSI AFTER 10 MINUTES: <u>9</u> W.C.	<u>6PC</u>
	PRESSURE AS LEFT: PSI PSI PRESSURE AS LEFT: <u>13.6</u> W.C.	<u>400.00</u>
X	PIPING PRESSURE TEST	INV. TOTAL
CUSTOMER SIGNATURE	START PSIG FINISH PSIG	AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

2-25-25 X