



congerlpgas.com

INVOICE / WORK ORDER NO.

111483

146 S. Ridge Ave.  
Tifton, GA 31794  
(229) 386-5574

306 S. Main St.  
Sylvester, GA 31791  
(229) 776-7336

604-B N. Broadfoot Blvd.  
Vidalia, GA 30474  
(912) 537-8722

3117 Veterans Parkway S.  
Moultrie, GA 31788  
(229) 985-6942

NAME Amber McDowell RT# \_\_\_\_\_ RT. SEQ. \_\_\_\_\_ ACCT # 03-19130 DATE 1-2-25 INT BP  
Rain Coleman

MAILING ADDRESS \_\_\_\_\_ CO. \_\_\_\_\_ CITY \_\_\_\_\_  
ADDRESS 2915 Thigpen Trail APT/LOT NO. \_\_\_\_\_  
CITY Harts Field STATE GA ZIP CODE 31756  
NEW CUSTOMER INFORMATION  
S.S. NO. \_\_\_\_\_ DELV \_\_\_\_\_  
HOME PH \_\_\_\_\_ RENT \_\_\_\_\_  
WORK PH \_\_\_\_\_ CREDIT \_\_\_\_\_  
LITE PILOT \_\_\_\_\_ PC \_\_\_\_\_  
EMPLOYER \_\_\_\_\_  
DR. \_\_\_\_\_ USE \_\_\_\_\_ LEASE \_\_\_\_\_

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED \_\_\_\_\_  
For 347 Coleman rd  
email: \_\_\_\_\_  
cell # \_\_\_\_\_  
**PAY BILL ONLINE @congerlpgas.com**  
DIRECTIONS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
600	FEET 1/2 TRAC				357.00
1	TRAC TEE				64.00
1	Wall Flange				39.95
2	Regulators				129.90
1	Flex Con				19.95
3	cut offs				59.95
1	RL 75e	RL 75e	ALUA151601		999.95
1	G 10 - 24/30.01 up.		2018765		1699.95

WORK PERFORMED: <u>Installed water Heater</u>	REGULATION INFORMATION	APPLIANCES/ EQUIP. SOLD	COVS
<u>Stove &amp; logs for new gas</u>	MAKE: <u>Regu</u>	MODEL: <u>B46R</u>	<u>WH</u>
<u>lines no leaks in system</u>	DATE CODE: <u>8-23</u>	VENT: <u>down</u>	<u>WP</u>
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE			
		TANK RENT	<u>CF</u>
			<u>14.95</u>

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX	
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>		HIGH:	1st Stage 2nd Stage	LOW	
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>		START LOCK-UP:	PSI PSI	START LOCK-UP:	12.2 W.C.
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF:	PSI PSI	TANK OFF:	9 W.C.
		PRESSURE	PSI PSI	PRESSURE	9 W.C.
		AFTER 10 MINUTES:	PSI PSI	AFTER 10 MINUTES:	9 W.C.
		PRESSURE AS LEFT:	PSI PSI	PRESSURE AS LEFT:	12.2 W.C.
X _____		PIPING PRESSURE TEST		INV. TOTAL	
CUSTOMER SIGNATURE		START	PSIG	FINISH	PSIG
				AMOUNT RECEIVED	
				4083.17	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY; BLUE/OFFICE COPY