



HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

INVOICE

No 11152 ✓

NAME	<u>Axel White</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>3364 Ben Carter Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-278-4370</u>	DATE COMPLETED	<u>1-27-25</u>
LOCATION		TERMS	

INSTRUCTIONS run gas lines, install tankless water heater, gas logs, firebox, cooktop, & gas tank

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE199e tankless water heater w/isolation valves, serial # SH.UA-116163		1500 00
1	24" Peterson G10-24/30-15(M)P gas log set w/ V/Lh remote		1248 50
1	36" Breckenridge fire box w/ porcelain liner, T-stat blower		1188 00
82	gallon of propane	2 89	236 98
1	Rego LV3403B4 second stage regulator		59 95
30'	1/2" True pipe	5 09	152 70
27'	1/2" coated copper tubing	3 29	88 83
75'	3/8" coated copper tubing	2 79	209 25
all	other gas fittings, Ox box, cut off valves		209 30

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X
CUSTOMER'S SIGNATURE

SERVICES PERFORMED

ran all gas lines, set 120 gallon tank, installed tankless water heater, fire box, gas logs, gas cooktop, converted cooktop to L.P., ran pressure check, lit & checked out appliances

TOTAL TIME _____ HOURS

TOTAL MATERIAL

4893 51

LABOR

800 00

SUBTOTAL

SALES TAX

391 48

TOTAL DUE

6084 99

AMOUNT RECEIVED

RECEIVED \$

RECEIVED BY

DATE

SERVICES RECEIVED BY

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>120</u>	SIZE	START LOCK UP:	START T. JACK UP:
S/N: <u>1527957</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>82 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 1/27/25
 Name Axel White Company Sikes Propane, Inc.
 Address 3364 Ben Carter Rd. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-278-4370 (Home) _____

Appliance Check

Appliance	water heater	gas Loss	gas cooktop			
Manufacturer	<u>Rinnai</u>	<u>Peterson</u>	<u>Frigidaire</u>			
Model #	<u>RE199e</u>	<u>G10-24/30-15CM/P</u>	<u>GCCG3048 AS</u>			
Serial #	<u>SH.4A-116163</u>	<u>2057293</u>	<u>1F40590028</u>			
BTU's	<u>199,000</u>	<u>37,000</u>	<u>48,000</u>			
Burner / Cont. Chamber	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>	<u>installed</u>			
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Venting System	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Age	<u>new</u>	<u>new</u>	<u>new</u>			
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>1527957</u>	<u>Quality Steel</u>	<u>2024</u>	<u>ok</u>	<u>new</u>	<u>09D22</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>105psi.</u>	<u>105psi.</u>	<u>10min.</u>	<u>0</u>	<u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2" + 3/8"</u>	<u>ok</u>
<u>trace-pipe</u>	<u>1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>9in.wc</u>	<u>9in.wc</u>	<u>10min.</u>	<u>0</u>	<u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection		
<u>first</u>	<u>Rego</u>	<u>06D2024 / LV4403TR9</u>	<u>u-c</u>		
<u>second</u>	<u>Rego</u>	<u>06C2022 / LV3403B4</u>	<u>down</u>		

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.