



HOME OWNED & OPERATED

INVOICE
No. 10802

Posted 2-3-25

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>James Gardner</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>98 LL Sellers Rd.</u>	DATE ORDERED	<u>5-23-24 start</u>
CITY/STATE/ZIP	<u>Hazlehurst GA</u>	DATE PROMISED	
PHONE	<u>912-347-2139</u>	DATE COMPLETED	<u>1-31-25</u>
LOCATION		TERMS	

INSTRUCTIONS

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE199e tankless water heater w/isolation valves, serial # SB.4A-017307		1500 00
1	Rinnai RGBRE recess box		319 00
1	Rinnai RE190e tankless water heater w/isolation valves, serial # RG.4A-098880		1050 00
1	42" Monessen Attribute firebox w/ pan , Black glass panels, fan kit		1600 00
1	Monessen 30" Stony Creek Log set w/enhancement ^{K.T.} with remote		1389 00
325	gallon of propane	2.89	939 25

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

install appliances

TOTAL MATERIAL

6797 25

TOTAL TIME HOURS

LABOR

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

[Signature]

SUBTOTAL

SALES TAX

543 78

TOTAL DUE

7,341 03

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE:	SIZE	START LOCK UP:	START LOCK UP:
S/N:	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING:	GALLONS OR READING:	AFTER 10 MINUTES PRESSURE AS LEFT:	AFTER 10 MINUTES PRESSURE AS LEFT:

AMOUNT

RECEIVED \$

RECEIVED BY

DATE

SERVICES RECEIVED BY

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 1/31/25
 Name James Gardner Company Sikes Propane, Inc.
 Address 98 LL Sellers Rd Call Taken By _____
 City Hazlehurst State GA Zip 31539 Telephone (Cell) 912-347-2139 (Home) _____

Appliance Check

Appliance	water heater	water heater	gas Loss	Generator		
Manufacturer	Rinnai	Rinnai	Hearth + Home T.	Generac		
Model #	RE199a	RE140a	NB24PV	G0072101		
Serial #	SB,UA-017307	RG,UA-098880	VF0407230	3014814485		
BTU's	199,000	140,000	36,000	355,000		
Burner / Com. Chamber	ok	ok	ok	ok		
Man. Shutoff / Sed. Trap	installed	installed	installed	installed		
Control / Pilot Safety System	ok	ok	ok	ok		
Venting System	ok	ok	ok	ok		
Age	new	new	new	new		
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
500	25E027843	American W.	1996	ok	ok	10-95	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
90 psi.	90 psi.	10 min.	0	0

Piping Check

Materials	Size	Cover / Protection
coated copper	1/2" + 3/8"	ok

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
9 in. wc.	9 in. wc.	10 min.	0	0

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
first	Rago	06D2024 / LV4403TR9	u c
second	Rago	04C2024 / LV4403R6R	down
second	Rago	06C2022 / LV3403R4	down
second	Rago	09D2023 / LV4403Y4	down
second	Maxi-trap	0325-31 + 0325-5L	horizontal

Comments: Please note all repairs and corrections made along with any recommended actions.